
PART 1 GENERAL**1.1 RELATED DOCUMENTS**

- A. Drawings and general provisions of the Contract, including General Conditions and Division 1 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section Includes:
 - 1. Joints in or between fire-resistance-rated constructions.
 - 2. Joints at exterior curtain-wall/floor intersections.
 - 3. Joints in smoke barriers.
- B. Related Sections:
 - 1. Division 1 Section "Sustainable Design Requirements".
 - 2. Division 5 Section "Architectural Joint Systems" for fire-resistive architectural joint systems.
 - 3. Division 7 Section "Through-Penetration Firestop Systems" for penetrations in fire-resistance-rated walls, horizontal assemblies, and smoke barriers.

1.3 QUALITY ASSURANCE

- A. The work of this section shall be performed by a company which specializes in the type of fire-resistive joint systems work required for this Project, with a minimum of 5 years of documented successful experience and shall be performed by skilled workmen thoroughly experienced in the necessary crafts.
 - 1. Work shall be performed in compliance with Owner's insurance underwriters' requirements and UL approvals and testing for materials, assemblies and procedures.
- B. Manufacturer shall specialize in manufacturing the type of fire-resistive joint systems specified in this section, with a minimum of 5 years of documented successful experience, and have the facilities capable of meeting all requirements of Contract Documents as a single-source responsibility and warranty.
- C. Installer Qualifications: A firm experienced in installing fire-resistive joint systems similar in material, design, and extent to that indicated for this Project, whose work has resulted in construction with a record of successful performance. Qualifications include having the necessary experience, staff, and training to install manufacturer's products per specified requirements. Manufacturer's willingness to sell its fire-resistive joint system products to Contractor or to Installer engaged by Contractor does not in itself confer qualification on buyer.
- D. Fire-Test-Response Characteristics: Fire-resistive joint systems shall comply with the following requirements:
 - 1. Fire-resistive joint system tests are performed by a qualified testing agency acceptable to authorities having jurisdiction.
 - 2. Fire-resistive joint systems are identical to those tested per testing standard referenced in "Fire-Resistive Joint Systems" Article. Provide rated systems complying with the following requirements:
 - a. Fire-resistive joint system products bear classification marking of qualified testing agency.
 - b. Fire-resistive joint systems correspond to those indicated by reference to designations listed by the following:
 - 1) UL in its "Fire Resistance Directory."
- E. Preinstallation Conference: Conduct conference at Project site.
- F. Manufacturer's identification tags or marks are not acceptable on surfaces which will remain exposed to view after installation.
 - 1. Evidence of "patching" after removal of tags or marks is not acceptable.

1.4 SUBMITTALS

- A. Submit the following according to Conditions of the Construction Contract and Division 1 Specification Sections.
- B. Product Data: For each type of product indicated.
- C. LEED Submittal:
 - 1. Product Data for Credit EQ 4.1: For fire-resistive joint systems, including printed statement of VOC content.

- D. Product Schedule: For each fire-resistive joint system. Include location and design designation of qualified testing agency.
 - 1. Where Project conditions require modification to a qualified testing agency's illustration for a particular fire-resistive joint system condition, submit illustration, with modifications marked, approved by fire-resistive joint system manufacturer's fire-protection engineer as an engineering judgment or equivalent fire-resistance-rated assembly.
- E. Qualification Data: For qualified Installer.
- F. Installer Certificates: From Installer indicating fire-resistive joint systems have been installed in compliance with requirements and manufacturer's written recommendations.
- G. Product Test Reports: Based on evaluation of comprehensive tests performed by a qualified testing agency, for fire-resistive joint systems.
- H. Hazardous Materials Notification: In the event no product or material is available that does not contain asbestos, PCB or other hazardous materials as determined by the Owner, a "Material Safety Data Sheet" (MSDS) equivalent to OSHA Form 20 shall be submitted for that proposed product or material prior to installation.
- I. Asbestos and PCB Certification: After completion of installation, but prior to Substantial Completion, Contractor shall certify in writing that products and materials installed, and processes used, do not contain asbestos or polychlorinated biphenyls (PCB), using format in Article 3 of General Conditions.

1.5 DELIVERY, STORAGE, AND HANDLING

- A. Comply with General Conditions and Division 1 Section "Product Requirements".

1.6 PROJECT CONDITIONS

- A. Environmental Limitations: Do not install fire-resistive joint systems when ambient or substrate temperatures are outside limits permitted by fire-resistive joint system manufacturers or when substrates are wet due to rain, frost, condensation, or other causes.
- B. Install and cure fire-resistive joint systems per manufacturer's written instructions using natural means of ventilation or, where this is inadequate, forced-air circulation.

1.7 COORDINATION

- A. Coordinate construction of joints to ensure that fire-resistive joint systems are installed according to specified requirements.
- B. Coordinate sizing of joints to accommodate fire-resistive joint systems.
- C. Notify Owner's testing agency at least seven days in advance of fire-resistive joint system installations; confirm dates and times on day preceding each series of installations.

1.8 WARRANTY

- A. Comply with General Conditions and Division 1 Section "Product Requirements".

PART 2 PRODUCTS

2.1 UNAUTHORIZED MATERIALS

- A. Materials and products required for work of this section shall not contain asbestos, polychlorinated biphenyls (PCB) or other hazardous materials identified by the Owner.

2.2 ACCEPTABLE MANUFACTURERS

- A. Products of the manufacturers specified in this section establish the minimum functional, aesthetic and quality standards required for work of this section.
- B. Substitutions: Comply with General Conditions using form in Division 1 Section "Substitution Request Form".

2.3 FIRE-RESISTIVE JOINT SYSTEMS

- A. Where required, provide fire-resistive joint systems that are produced and installed to resist spread of fire according to requirements indicated, resist passage of smoke and other gases, and maintain original fire-resistance rating of assemblies in or between which fire-resistive joint systems are installed. Fire-resistive joint systems shall accommodate building movements without impairing their ability to resist the passage of fire and hot gases.
- B. Joints in or between Fire-Resistance-Rated Construction: Provide fire-resistive joint systems with ratings determined per ASTM E1966 or UL 2079:
1. Joints include those installed in or between fire-resistance-rated walls, floor or floor/ceiling assemblies, and roofs or roof/ceiling assemblies.
 2. Fire-Resistance Rating: Equal to or exceeding the fire-resistance rating of construction they will join.
 3. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. A/D Fire Protection Systems Inc.
 - b. CEMCO.
 - c. Fire Trak Corp.
 - d. Grace Construction Products.
 - e. Hilti, Inc.
 - f. Johns Manville.
 - g. Nelson Firestop Products.
 - h. NUCO Inc.
 - i. Passive Fire Protection Partners.
 - j. RectorSeal Corporation.
 - k. Specified Technologies Inc.
 - l. 3M Fire Protection Products.
 - m. Tremco, Inc.; Tremco Fire Protection Systems Group.
 - n. USG Corporation.
- C. Joints at Exterior Curtain-Wall/Floor Intersections: Provide fire-resistive joint systems with rating determined by ASTM E119 based on testing at a positive pressure differential of 0.01-inch wg (2.49 Pa) or ASTM E2307.
1. Fire-Resistance Rating: Equal to or exceeding the fire-resistance rating of the floor assembly.
 2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. Thermafiber, Inc.
 - b. USG Corporation.
 - c. Roxul.
 3. Perimeter Fire Containment System
 - a. Curtainwall Insulation and Mullion Cover: Semi-rigid board insulation produced by combining slag-wool or rock-wool fibers with thermosetting resin binders, aluminum foil scrim backing, and complying with the following:
 - 1) ASTM C 612, Type 3.
 - 2) Nominal density of 8 and 4 lb/cu. ft. as required by test assembly.
 - 3) ASTM E 119 fire rating as indicated, but not less than 2 hours.
 - b. Safing Material: Semi-rigid board insulation produced by combining slag-wool fibers with thermosetting resin binders, unfaced, and complying with to the following:
 - 1) ASTM C 612, Type IA and IB.
 - 2) Nominal density of 4 lb/cu. ft.
 - 3) ASTM E 119 fire rating as indicated, but not less than 2 hours.
 - c. Coating Material: Specified Technologies, Inc. SpecSeal AS200 Elastomeric Spray or SpecSeal Fast Tack Spray.
 - d. Impaling Pins: 12 gage steel pins swaged to galvanized steel angles for screw attachment to glazed aluminum wall system aluminum framing.
 - e. Reinforcing Angles: Galvanized steel angles of size, thickness, and finish suitable for application.
- D. Joints in Smoke Barriers: Provide fire-resistive joint systems with ratings determined per UL 2079.
1. L-Rating: Not exceeding 5.0 cfm/ft (0.00775 cu. m/s x m) of joint at 0.30 inch wg (74.7 Pa) at both ambient and elevated temperatures.
 2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. A/D Fire Protection Systems Inc.
 - b. Grace Construction Products.
 - c. Hilti, Inc.
 - d. Johns Manville.

- e. Nelson Firestop Products.
 - f. NUCO Inc.
 - g. Passive Fire Protection Partners.
 - h. RectorSeal Corporation.
 - i. Specified Technologies Inc.
 - j. 3M Fire Protection Products.
 - k. Tremco, Inc.; Tremco Fire Protection Systems Group.
 - l. USG Corporation.
- E. Exposed Fire-Resistive Joint Systems: Provide products with flame-spread and smoke-developed indexes of less than 25 and 450, respectively, as determined per ASTM E84.
- F. VOC Content: Provide fire-resistive joint systems that comply with the following limits for VOC content when calculated according to 40 CFR 59, Subpart D (EPA Method 24):
- 1. Architectural Sealants: 250 g/L.
 - 2. Sealant Primers for Nonporous Substrates: 250 g/L.
 - 3. Sealant Primers for Porous Substrates: 775 g/L.
- G. Accessories: Provide components of fire-resistive joint systems, including primers and forming materials, that are needed to install fill materials and to maintain ratings required. Use only components specified by fire-resistive joint system manufacturer and approved by the qualified testing agency for systems indicated.

PART 3 EXECUTION

3.1 EXAMINATION

- A. Examine substrates and conditions, with Installer present, for compliance with requirements for joint configurations, substrates, and other conditions affecting performance of the Work.
- B. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 PREPARATION

- A. Surface Cleaning: Clean joints immediately before installing fire-resistive joint systems to comply with fire-resistive joint system manufacturer's written instructions and the following requirements:
- 1. Remove from surfaces of joint substrates foreign materials that could interfere with adhesion of fill materials.
 - 2. Clean joint substrates to produce clean, sound surfaces capable of developing optimum bond with fill materials. Remove loose particles remaining from cleaning operation.
 - 3. Remove laitance and form-release agents from concrete.
- B. Priming: Prime substrates where recommended in writing by fire-resistive joint system manufacturer using that manufacturer's recommended products and methods. Confine primers to areas of bond; do not allow spillage and migration onto exposed surfaces.
- C. Masking Tape: Use masking tape to prevent fill materials of fire-resistive joint system from contacting adjoining surfaces that will remain exposed on completion of the Work and that would otherwise be permanently stained or damaged by such contact or by cleaning methods used to remove stains. Remove tape as soon as possible without disturbing fire-resistive joint system's seal with substrates.

3.3 INSTALLATION

- A. General: Install fire-resistive joint systems to comply with manufacturer's written installation instructions and published drawings for products and applications indicated.
- B. Install forming materials and other accessories of types required to support fill materials during their application and in position needed to produce cross-sectional shapes and depths required to achieve fire ratings indicated.
- 1. After installing fill materials and allowing them to fully cure, remove combustible forming materials and other accessories not indicated as permanent components of fire-resistive joint system.
- C. Install fill materials for fire-resistive joint systems by proven techniques to produce the following results:
- 1. Fill voids and cavities formed by joints and forming materials as required to achieve fire-resistance ratings indicated.
 - 2. Apply fill materials so they contact and adhere to substrates formed by joints.

3. For fill materials that will remain exposed after completing the Work, finish to produce smooth, uniform surfaces that are flush with adjoining finishes.

3.4 IDENTIFICATION

- A. Identify fire-resistive joint systems with preprinted metal or plastic labels. Attach labels permanently to surfaces adjacent to and within 6 inches (150 mm) of joint edge so labels will be visible to anyone seeking to remove or penetrate joint system. Use mechanical fasteners or self-adhering-type labels with adhesives capable of permanently bonding labels to surfaces on which labels are placed. Include the following information on labels:
 1. The words "Warning - Fire-Resistive Joint System - Do Not Disturb. Notify Building Management of Any Damage."
 2. Contractor's name, address, and phone number.
 3. Designation of applicable testing agency.
 4. Date of installation.
 5. Manufacturer's name.
 6. Installer's name.

3.5 FIELD QUALITY CONTROL

- A. Inspecting Agency: Owner will engage a qualified testing agency to perform tests and inspections.
- B. Where deficiencies are found or fire-resistive joint systems are damaged or removed due to testing, repair or replace fire-resistive joint systems so they comply with requirements.
- C. Proceed with enclosing fire-resistive joint systems with other construction only after inspection reports are issued and installations comply with requirements.

3.6 CLEANING AND PROTECTING

- A. Clean off excess fill materials adjacent to joints as the Work progresses by methods and with cleaning materials that are approved in writing by fire-resistive joint system manufacturers and that do not damage materials in which joints occur.
- B. Provide final protection and maintain conditions during and after installation that ensure fire-resistive joint systems are without damage or deterioration at time of Substantial Completion. If damage or deterioration occurs despite such protection, cut out and remove damaged or deteriorated fire-resistive joint systems immediately and install new materials to produce fire-resistive joint systems complying with specified requirements.

3.7 FIRE-RESISTIVE JOINT SYSTEM SCHEDULE

- A. Where UL-classified systems are indicated, they refer to system numbers in UL's "Fire Resistance Directory" under product Category XHBN or Category XHDG.
- B. Floor-to-Floor, Fire-Resistive Joint Systems:
 1. UL-Classified Systems: FF-S 0000-0999.
 2. Assembly Rating: Match rating of floor assembly.
 3. Nominal Joint Width: As indicated.
- C. Wall-to-Wall, Fire-Resistive Joint Systems:
 1. UL-Classified Systems: WW-S-0000-0999.
 2. Assembly Rating: Match rating of wall assembly.
 3. Nominal Joint Width: As indicated.
- D. Floor-to-Wall, Fire-Resistive Joint Systems:
 1. UL-Classified Systems: FW-S-0000-0999.
 2. Assembly Rating: Match rating of wall assembly.
 3. Nominal Joint Width: As indicated.
- E. Head-of-Wall, Fire-Resistive Joint Systems:
 1. UL-Classified Systems: HW-S-0000-0999.
 2. Assembly Rating: Match rating of wall assembly.
 3. Nominal Joint Width: As indicated.

- F. Bottom-of-Wall, Fire-Resistive Joint Systems:
 - 1. UL-Classified Systems: BW-S-0000-0999.
 - 2. Assembly Rating: Match rating of wall assembly.
 - 3. Nominal Joint Width: As indicated.

- G. Perimeter Fire-Resistive Joint Systems:
 - 1. UL-Classified Perimeter Fire-Containment Systems: CW-D-2039.
 - 2. Integrity Rating: 1 hours.
 - 3. Insulation Rating: 1/4 hour.
 - 4. Linear Opening Width: 4 inches (203 mm) maximum.

END OF SECTION