

PART 1 GENERAL**1.1 RELATED DOCUMENTS**

- A. The requirements of the General Conditions, Supplementary Conditions and the following Specification sections apply to all Work herein:
1. Division 22 Specifications - All sections

1.2 DESIGN CONDITIONS

	<u>Working Pressure</u>	<u>Normal Operating Temperature Range</u>
Domestic Cold Water System:		
Low Level **	475	
Pressure to any fixture shall be limited to 80 psig maximum at no flow conditions at any domestic water system operating condition.		
Domestic Hot Water System:	150	120 to 140

** See Drawings for extent of low and high level requirements on each system.

- A. Range of indoor design goals for HVAC and Plumbing System sound control for all occupied spaces shall have an NC 40 criteria curve range as otherwise specified in Section 22 00 10.
- B. Approximate Ground Floor elevation above sea level: 15 Ft.

PART 2 PRODUCTS (Not Used)**PART 3 EXECUTION (Not Used)**

END OF SECTION