

**PART 1 GENERAL****1.1 RELATED DOCUMENTS**

- A. The requirements of the General Conditions, Supplementary Conditions and the following specification sections apply to all Work herein:
1. Section 26 00 10 - General Requirements
  2. Section 26 00 20 - Scope of Work
  3. Section 26 05 19 - Electrical Conductors - 600 Volts
  4. Section 26 05 26 - Grounding and Bonding
  5. Section 26 08 13 - Testing
  6. Section 26 51 13 - Lighting Fixtures and Lamps

**1.2 SUMMARY**

- A. Furnish and install all architectural lighting fixtures and lamps as specified by the Project Lighting Consultant and as indicated on the Drawings. Refer to the Specifications hereinafter for all Work related to the architectural lighting fixtures for this Project.

**1.3 REFERENCE STANDARDS**

- A. All equipment and material to be furnished and installed on this Project shall be UL or ETL listed, in accordance with the requirements of the authorities having jurisdiction, and suitable for its intended use on this Project.

**1.4 SUBMITTALS**

- A. The following submittal data shall be furnished according to the General Conditions and Section 26 00 10 and shall include, but not be limited to:
1. Lighting fixtures complete with physical dimensions, materials, connector details, voltage, current, installation details, air handling capability, etc.
  2. Lamps complete with base or pin configuration, lumen rating, life expectancy, color temperature, starting characteristics, etc.
  3. Samples where required by these Specifications.
- B. All items or equipment listed above with asterisks (\*) shall be certified by the manufacturer using Manufacturer Certification "MCA" as set forth in Section 26 00 10. See Section 26 00 10 for certification requirements.

**1.5 WARRANTY**

- A. Comply with the requirements of the General Conditions and Section 26 00 10.

**PART 2 PRODUCTS****2.1 ACCEPTABLE MANUFACTURERS**

- A. Refer to the Specifications hereinafter for manufacturer requirements related to the architectural lighting fixtures for this Project. These Specifications have been prepared by the Project Lighting Consultant.

**PART 3 EXECUTION****3.1 INSTALLATION**

- A. Refer to the Specifications hereinafter for installation requirements related to the architectural lighting fixtures for this Project. These Specifications have been prepared by the Project Lighting Consultant.

**3.2 FIELD TESTING**

- A. Refer to Section 26 08 13 for additional testing requirements for architectural lighting fixtures and lamps.

**END OF SECTION**