



GENERAL NOTES

1. FOR GENERAL NOTES, SYMBOLS, AND ABBREVIATIONS, REFER TO SHEET E-001.
2. UNLESS OTHERWISE NOTED, LIGHT LINEWEIGHT INDICATES EXISTING EQUIPMENT TO REMAIN AND HEAVY LINEWEIGHT INDICATES NEW WORK.
3. SUBCONTRACTORS MUST FIELD VERIFY LOCATION OF EXISTING EQUIPMENT AND EQUIPMENT TO BE DISCONNECTED AND REMOVED.
4. SUBCONTRACTOR MUST FIELD VERIFY CIRCUITS INDICATED AND LOADS SERVED BY THEM.
5. SUBCONTRACTORS MUST WORK CLOSELY WITH MECHANICAL SUBCONTRACTOR TO VERIFY PHASING OF DEMOLITION. THIS IS TO AVOID ANY UNNECESSARY OR UNPLANNED OUTAGES FOR EQUIPMENT OR THE FACILITY.
6. SUBCONTRACTOR MUST REFER TO DIVISION 1 SPECIFICATIONS FOR CONSTRUCTION SEQUENCING AND PHASING.
7. REFER TO SHEETS E-801 AND E-802 FOR ADDITIONAL WORK AT ELECTRICAL PANELS.
8. IT HAS BEEN FIELD VERIFIED THAT THERE ARE EXISTING MAINTENANCE RECEPTACLES WITHIN 25' OF MECHANICAL EQUIPMENT.
9. SUBCONTRACTOR MUST VERIFY THAT NEW ELECTRICAL EQUIPMENT HAVE PROPER WORKING CLEARANCE PRIOR TO INSTALLATION.
10. ALL NEW CONDUITS MUST BE PAINTED TO MATCH EXISTING IN AREA.

KEYED NOTES

1. PROVIDE 2#12, #12G - 3/4\"/>

Sheet Title
ELECTRICAL OVERALL PLAN -
SECOND FLOOR

Dwg. No.
PLE2021-0432-0010D

Sht. No.
E-102