



GENERAL NOTES	
1. FOR GENERAL NOTES, SYMBOLS, AND ABBREVIATIONS, REFER TO SHEET E-001.	
2. UNLESS OTHERWISE NOTED, LIGHT LINEWEIGHT INDICATES EXISTING EQUIPMENT TO REMAIN AND HEAVY LINEWEIGHT INDICATES NEW WORK.	
3. REFER TO SHEETS E-801 AND E-802 FOR ADDITIONAL WORK AT ELECTRICAL PANELS.	
4. VERIFY EXISTING CONDITIONS MEET NEC STANDARDS.	
# KEYED NOTES	
1. EXISTING PANEL TO BE AFFECTED BY THIS PROJECT. COORDINATE SHUTDOWN WITH SUBCONTRACT TECHNICAL REPRESENTATIVE DURING CONSTRUCTION. SEE SHEET E-801 AND E-802 FOR ADDITIONAL WORK.	
2. PROVIDE NEW 480V-3PH-3W PANELBOARD IN ROOM 1400. REUSE EXISTING CONDUIT TO RECONNECT EQUIPMENT.	
3. ALL CONNECTED LOADS WHETHER NEW OR EXISTING MUST BE RELABELED.	
4. PROVIDE NEW CONDUCTORS FROM NEW PANEL 590A11B TO RE-FEED EXISTING EQUIPMENT. EXISTING CONDUIT MUST REMAIN AND TO BE REUSED FOR NEW WORK.	
5. PROVIDE 400A ENCLOSED CIRCUIT BREAKER. ENCLOSED BREAKER MUST HAVE PADLOCKABLE HANDLE. THE ENCLOSURE MUST BE LOCKED WHEN THE BREAKER IS CLOSED.	
Sheet Title	
ELECTRICAL ONE LINE DIAGRAM	
Dwg. No.	
PLE2021-0432-0013D	
Sht. No.	
E-701	