



- ## GENERAL NOTES

1. FOR GENERAL NOTES, SYMBOLS, AND ABBREVIATIONS, REFER TO SHEET E-001.
2. UNLESS OTHERWISE NOTED, LIGHT LINEWEIGHT INDICATES EXISTING EQUIPMENT TO REMAIN AND HEAVY LINEWEIGHT INDICATES EQUIPMENT TO BE MODIFIED.
3. SUBCONTRACTORS MUST FIELD VERIFY LOCATION OF EXISTING EQUIPMENT AND EQUIPMENT TO BE INSTALLED.
4. SUBCONTRACTOR MUST FIELD VERIFY CIRCUITS AND LOADS SERVED BY THEM.
5. SUBCONTRACTOR MUST UPDATE MODIFIED PANELBOARD SCHEDULES.
6. PANEL SCHEDULES FOR AFFECTED PANELS ARE SHOWN. COORDINATE EQUIPMENT SHUTDOWN WITH CONSTRUCTION MANAGER / SUBCONTRACT TECHNICAL REPRESENTATIVE DURING CONSTRUCTION.
7. CONDUCTOR SPLICES ARE NOT ALLOWED WITHOUT LEAD ELECTRICAL ENGINEER APPROVAL.

## # KEYED NOTES

1. DISCONNECT AND REMOVE EXISTING CIRCUIT BREAKER IN EXISTING PANEL. REPLACE WITH NEW 2P-208V-30A CIRCUIT BREAKER IN EXISTING PANEL TO SERVE NEW LOAD.
2. DISCONNECT AND REMOVE EXISTING CIRCUIT BREAKER IN EXISTING PANEL. REPLACE WITH NEW 3P-480V-80A CIRCUIT BREAKER TO SERVE NEW LOAD. NEW CIRCUIT BREAKER CHARACTERISTICS MUST MATCH EXISTING.
3. DISCONNECT AND REMOVE EXISTING CIRCUIT BREAKER IN EXISTING PANEL. REPLACE WITH NEW 3P-480V-110A CIRCUIT BREAKER TO SERVE NEW LOAD. NEW CIRCUIT BREAKER CHARACTERISTICS MUST MATCH EXISTING.
4. DISCONNECT AND REMOVE EXISTING CIRCUIT BREAKER IN EXISTING PANEL. REPLACE WITH NEW 2P-208V-20A CIRCUIT BREAKER IN EXISTING PANEL TO SERVE NEW LOAD.

Sheet Title

## ELECTRICAL PANEL SCHEDULES

Dwg. No.

PLE2021-0432-0017D

Sht. No.

E-804