



- GENERAL NOTES**
1. FOR GENERAL NOTES, SYMBOLS, AND ABBREVIATIONS, REFER TO SHEET E-001.
 2. UNLESS OTHERWISE NOTED, LIGHT LINEWEIGHT INDICATES EXISTING EQUIPMENT TO REMAIN AND HEAVY LINEWEIGHT INDICATES DEMOLITION WORK.
 3. SUBCONTRACTORS MUST FIELD VERIFY LOCATION OF EXISTING EQUIPMENT AND EQUIPMENT TO BE DISCONNECTED AND REMOVED.
 4. SUBCONTRACTOR MUST FIELD VERIFY CIRCUITS INDICATED AND LOADS SERVED BY THEM.
 5. SUBCONTRACTORS MUST WORK CLOSELY WITH MECHANICAL SUBCONTRACTOR TO VERIFY PHASING OF DEMOLITION. THIS IS TO AVOID ANY UNNECESSARY OR UNPLANNED OUTAGES FOR EQUIPMENT OR THE FACILITY.
 6. SUBCONTRACTOR MUST REFER TO DIVISION 1 SPECIFICATIONS FOR CONSTRUCTION SEQUENCING AND PHASING.
 7. REFER TO SHEETS E-801, E-802 AND E-803 FOR ADDITIONAL WORK AT ELECTRICAL PANELS.
 8. CONDUIT ROUTING IS FOR DIAGRAMMATIC PURPOSE ONLY. SUBCONTRACTOR MUST VERIFY EXACT CONDUIT ROUTES
 9. DEMOLITION WORK MUST COMPLY WITH NEC ARTICLE 725.25 AND 800.25.

- # KEYED NOTES**
1. DEMOLISH EXISTING EQUIPMENT AND ALL ASSOCIATED DISCONNECTS, CONDUCTORS AND CONDUITS.

Sheet Title	
ELECTRICAL DEMOLITION PLAN - SECOND FLOOR	
Dwg. No.	PLE2021-0432-0005D
Sht. No.	ED102