

2 ENLARGED STERILIZATION EQUIPMENT AREA
1/16" = 1'-0"

1 ENLARGED FOOD SERVICE AREA - LOWER LEVEL
PLUMBING PLAN
1/16" = 1'-0"

GENERAL NOTES

- 1) SEE FOODSERVICE PLANS (KASBERG DRAWINGS) FOR PIPE SIZE, CONNECTIONS, FITURE TYPES AND EQUIPMENT IN FOODSERVICE AREA.
- 2) SEE PROCESSING DEPARTMENT PLAN BY STEINER FOR EQUIPMENT IN STERILIZATION AREA.
- 3) EXISTING CONNECTION TO FITURE AND EQUIPMENT SHALL NOT BE LONGER THAN 10' TO FITURES.
- 4) PROVIDE PRESSURE REGULATING VALVE FOR EACH EQUIPMENT IN STERILIZATION AREA. REFER TO MANUFACTURER'S SPECIFICATIONS.

KEYNOTES

- 1) CHANGE INTERCEPTOR LOCATED IN CLOSET. SEE DETAIL A 2 OF SHEET T1400.
- 2) 3/4" TMV & 3/4" CW DROP & CONNECT TO FITURES, INSTALL POINT OF USE TMV ON W/LINE.
- 3) CONNECT 3/4" HW & 3/4" CW WITH SDV TO GAWWASHER, PROVIDE W/ 1/4" WATTS SERIES LFNAB, LEAD FREE WITH PRESS. GAUGE.
- 4) 1/2" CW CONNECT TO 1/2" IN W/ WATTS (PROVIDE). CAP 1/2" CONNECTION FOR WATER FILTER TO BE CONNECTED TO KOLMAGER SELF FOOD SERVICE DIV'S FOR FILTER (INDICE NUMBER).
- 5) 3/4" CW DROP IN WALL FROM BACKFLOW PREVENTER & CAP COOK, FOR SODA SYSTEM.
- 6) 1" CW DROP IN WALL WITH HEADER.
- 7) CAP 1/2" PORTABLE CW FOR BEVERAGE DISPENSERS. SEE FOODSERVICE PLAN FOR TYPE OF BEVERAGE. CONNECT 3/4" DR FROM DISPENSERS & SHILL AW/ FLURSK-2.
- 8) DROP 3/4" HW, 3/4" CW, 1/2" CW & 1/2" CW IN WALL.
- 9) CAP 1 1/4" PIPING FOR FITURE.
- 10) CONNECT 3/4" HW, 3/4" CW, 3/4" CW & 1/2" COPING TO CLEAN-UP SINK (SPECIFIED BY VENDOR), TEE 3/4" HW, 3/4" CW & 1/2" COPING IN WALL AND CONNECT TO CLEANING SYSTEM (GAWWADPRO 11W ULTRASONIC CLEANER SPECIFIED BY VENDOR).
- 11) CONNECT 1 1/2" HW, 2" CW, 1 1/2" RD, 1/2" RD, 1/2" COPING TO CARRY EACH WARMER CONNECTION (MANSO EVOLUTION MEDIUM STERILIZER SPECIFIED BY VENDOR), TYPICAL.
- 12) CONNECT 1 1/4" CW, 1/2" CW, 1 1/2" RD & 1/2" CW TO EACH WARMER CONNECTERS, TYPICAL. USE MANSO TEE IN SINGLE CHAMBER SPECIFIED BY VENDOR, TYPICAL.
- 13) CONNECT 1 1/4" CW & 3/4" RD TO STEAM STERILIZER (MANSO EVOLUTION MEDIUM STERILIZER SPECIFIED BY VENDOR), TYPICAL.
- 14) CONNECT 1/2" CW PIPING DROP STERILIZER (MANSO EVOLUTION MEDIUM STERILIZER SPECIFIED BY VENDOR), TYPICAL.
- 15) CONNECT 1/2" CW DROP TO RO WATER TREATMENT SYSTEM.
- 16) 1/2" RD SUPPLY PIPING RISE (HEATWATER/HEALTHCARE WATER TREATMENT SYSTEM) WITH 100 GALLON STORAGE TANK (SPECIFIED BY VENDOR).
- 17) 1/2" CW PIPING DROP INSTALL GASK-CONNECT (TO BE CONNECTED TO CONVERTOR SYSTEM).
- 18) 2" W DN & 1-1/2" UP IN WALL.
- 19) 3/4" CW DRILL ABOVE FLOOR SINK.
- 20) 1/2" CW DROP IN WALL AND CONNECT TO WALL OUTLET.
- 21) SEE PLUMBING DIVS, # T1200L FOR CONT. OF PIPING.
- 22) 2" W DN & 2" V RISE.
- 23) 1" CW & 1 1/4" W DROP IN WALL.
- 24) 1" RD & 1 1/4" W PIPING DROP IN WALL. TEE 3/4" RD & 3/4" W & CONNECT TO ENDSCOPE REPROCESS MACHINE (SPECIFIED BY OTHER). INSTALL 2" STANDPIPE IN WALL WITH 2" W PIPING RISE IN WALL.
- 25) AIR COMPRESSOR (STERNE) MODEL STS-551514 30 GALLONS TANK FOR STERILIZATION PROCESS AREA (SPECIFIED BY OTHER).
- 26) CAP CONNECTIONS W/ 1" RD & 3/4" W PIPING AT WALL FOR FITURE ENDSCOPE PROCESS MACHINE. INSTALL 2" STAND PIPE WITH 1 1/2" W RISE IN WALL.
- 27) SOFT WATER SYSTEM BOTTLES SHALL BE ANCHORED TO WALL WITH DIRECT ACCESS REQUIREMENT.

KEYNOTES

KEY NOTE NUMBERS BELOW NOT APPLICABLE.



ARCHITECT
HKS ARCHITECTS, INC.
600 W. 5TH STREET, SUITE 1600
LOS ANGELES, CA 90028

STRUCTURAL ENGINEER
THAO TRUONG & GAMES
300 BLAKE AVENUE, 14TH FLOOR
PASADENA, CA 91107

MEP ENGINEER
THAO TRUONG & GAMES
300 BLAKE AVENUE, 14TH FLOOR
PASADENA, CA 91107

CIVIL ENGINEER
HWA CONSULTING ENGINEERS
4880 CENTER DRIVE, SUITE 200
LOS ANGELES, CA 90044

LANDSCAPE ARCHITECT
FRANCIS SCHUBERT LANDSCAPE ARCHITECTS
3142 COAST HIGHWAY
LAKELAND, FLORIDA 33809

ACOUSTICAL ENGINEER
NEWSON BROWN ACQUISITION LLC
2001 W. 86TH STREET, SUITE 300
SANTA MONICA, CA 90405

CODE
MPC, IBC, ASHRAE & ASSOCIATES, INC.
2009 SOUTH STATE AVENUE, SUITE 300
JANUARY, CALIFORNIA

HEALTHCARE TECHNOLOGY
GSA
100 GENERAL GEORGE PATTON DR.
FRANKLIN, TN 37067

SECURITY
TIC
10 TECHNOLOGY DRIVE
IRVING, CA 94039

FOOD SERVICES
K.W. BERRY CO.
2184 AIRWAY DRIVE
COSTA MESA, CA 92626




HEALTH SCIENCES CAMPUS

Norris Healthcare Consultation Center

TENANT IMPROVEMENT

2204 E Alcazar Street, Los Angeles, CA 90033

OWNER
UNIVERSITY OF SOUTHERN CALIFORNIA
300 N. SOTO STREET, SBA 423
LOS ANGELES, CA 90028



REV.	DESCRIPTION	DATE
1	Approved	02/01/15
2	Approved	01/22/15
3	Approved	01/22/15
4	Approved	01/22/15
5	Approved	11/02/14
6	Approved	11/02/14

PROJECT NUMBER:
18002.200

DATE:
04/20/15

ISSUE STATUS:
PLUMBING ENLARGED PLAN

SHEET TITLE:
PLUMBING ENLARGED PLAN

SHEET NO.:

TP-401

