

* SPECIAL NOTE: BEN FINNEY - NOT FOR CONSTRUCTION

GENERAL NOTES

A. REFER TO STRUCTURAL FOR ANCHORAGE OF BRACKETS IN EXISTING CONCRETE WALL.


- ① EXISTING GENERATOR EXHAUST STACK, SALVAGE AND RELOCATE AS SHOWN.
- ② EXISTING STACK BRACKETS AND HARDWARE, SALVAGE AND RELOCATE.
- ③ EXISTING FUEL TANK RELIEF AIR VENTS, LOCATE 9' NORTH.
- ④ FILL REVEALS AND FLOAT CEMENT PLASTER TO MATCH SURFACE OF ADJACENT REINFORCEMENT AND PAINT TO MATCH EXISTING.
- ⑤ COORDINATE CONSTRUCTION PHASING WITH OWNER PRIOR TO DEMO.
- ⑥ 3/4" CHAMFER ON CORNER (SEE STRUCTURAL).
- ⑦ FILL EXISTING REVEAL.
- ⑧ FILL FLUTES @ BRACKET LOCATIONS.
- ⑨ (4) EXISTING VENTS TO REMAIN.
- ⑩ RELOCATE EXISTING GENERATOR STACKS 13' NORTH.
- ⑪ (4) 3/4" EPOXY ANCHORS W/ HILTI RE 500 SD AND 6 1/2" IMBED.
- ⑫ (4) 3/4" THREADED RODS THROUGH WALL (SEE E2/A6/1e).
- ⑬ EXISTING CONCRETE WALL.
- ⑭ FIBERWRAP REINFORCEMENT (SEE STRUCTURAL).

MATERIAL LEGEND

- Area of Reinforcement (See Structural)
- Cement Plaster
- Steel
- Concrete

GIFFIN • BOLTE • JURGENS
ARCHITECTS

815 S.W. SECOND AVENUE - PORTLAND, OREGON 97204
(503) 223-0992 www.gbjarch.com FAX (503) 294-3961



MultiCare

EMERGENCY DEPARTMENT & CANCER CENTER EXPANSION

TACOMA, WASHINGTON

Date 09-26-2008
Scale AS SHOWN
Drawn By BPSC
Job No. 4034

EXTERIOR
DETAILS
L WING

A6
16