



MATERIAL LEGEND

Division 01 Thermal & Moisture Protection
01 95 13.A SEISMIC JOINT

Division 08 Openings
08 11 13.A CARD READER
B FUSH PLATE

Division 09 Finishes
09 06 00.A BASE AS SCHEDULED IN SECTION 09 06 00
09 21 00.A CONTROL JOINT
09 11 00.A WALL PANEL SYSTEM
09 83 10.A ACOUSTIC WALL TREATMENT (AUT-02)

Division 10 Specialties
10 26 00.A CORNER GUARD (1'-2" AFF UNLESS OTHERWISE NOTED)
B WALL PROTECTION (WP-02)
C NOT USED
D WALL PROTECTION (WP-04)
E WALL PROTECTION PANEL (WPP)

10 44 00.A RECESSED FIRE EXTINGUISHER CABINET

Division 22 Plumbing
22 00 00.A MEDICAL GAS VALVE CABINET
B MEDICAL GAS ALARM PANEL

Division 26 Electrical
26 00 00.A COVE LIGHT AS SCHEDULED
B WALL SCONCE
C NURSE CALL DOME LIGHT

GENERAL NOTES

1 WALL PROTECTION EXTENDS FULL HEIGHT.
INSTALL PER MANUFACTURER'S METAL STUD KIT INSTRUCTIONS.

2 COORDINATE LOCATION OF POWER AND DATA J-BOX WITH FINAL LOCATION OF TV BRACKET. POWER AND DATA J-BOXES TO BE PLACED BEHIND MONITOR BUT ASSURED THAT THE DATA AND POWER CONNECTION CAN BE MADE WITHOUT SHARP BENDS IN CONNECTOR LEADS.

3 ILLUMINATED AND SPACE RESERVED FOR ROOM SIGNAGE.

LEGEND

POSSIBLE LOCATION FOR GEL DISPENSER (FOIC)

SOAP DISPENSER (FOIC)

PAPER TOWEL DISPENSER (FOIC)

GLOVE DISPENSERS (FOIC)

SHARPS CONTAINER (FOIC)

NURSE CALL / PULL

INTERCOM

CODE CALL (SEE SECTION 11200)

EQUIPMENT TAG (SEE SECTION 11200)

NURSE CALL LIGHT

DUPLX RECEPTACLE W/ EMERGENCY POWER

QUADREX RECEPTACLE W/ EMERGENCY POWER

QUADREX RECEPTACLE

MEDICAL GAS OUTLETS:
A - MEDICAL AIR
O - OXYGEN
V - VACUUM

SLIDE

JUNCTION BOX

LIGHT SWITCH

TELEPHONE/DATA JACK COMBINED (STANDARD 4 JACKS PER PLATE)

WALL MOUNTED TELEPHONE

THERMOSTAT

24 HR CLOCK

BATTERY CLOCK

FIRE STROBE LIGHT

SEC. 12320 CASEWORK LEGEND
(UNLESS OTHERWISE NOTED)

OPEN CABINET W/ ADJ. SHELVES

2 ADJ. SHELVES

UNDERCABINET LIGHT FIXTURE W/P-LAM VALANCE

UPPER CABINET DOOR WITH FULL

P-LAM COUNTERTOP AND 4" BACKSLASH (OR OTHERWISE NOTED)

BASE CABINET

DRAWER WITH FULL

KEYBOARD TRAY FOIC

OPEN-KNEE SPACE

LOCK

HANGING FILE DRAWER = HF

LATERAL FILE DRAWER = LF

NOT TO SCALE