

ROOM AIR BALANCE - 3RD FLOOR

ROOM NO.	ROOM NAME	REQ. AIR CHANGES (ACPH)	REQ. PRESSURE RELATIONSHIPS	VOLUME (CU FT)	ACT AIR CHANGES (ACPH)	AIR QUANTITIES			
						SUPPLY AIR (CFM)	RETURN AIR (CFM)	EXHAUST AIR (CFM)	PRESS AIR (CFM)
3001	CORRIDOR	2	N/A	1,125	11	0	0	200	-200
3002	CORRIDOR	2	N/A	6,435	7	780	0	380	400
3003	MENS	10	N	1,032	10	0	0	180	-180
3004	WOMENS	10	N	992	11	0	0	180	-180
3005	WAIT	12	N	4,275	14	0	0	1,000	-1,000
3006	CORRIDOR	2	N/A	2,970	14	700	0	0	700
3007	ELEC.	0	N/A	567	16	150	0	150	0
3008	W.C.	0	N/A	891	13	0	0	200	-200
3009	WAIT	12	N	5,526	13	900	0	1,200	-300
3010	WAIT	12	N	7,389	11	1,200	0	1,410	-210
3011	RECEP.	4	N/A	11,529	6	1,100	0	700	400
3012	CORRIDOR	2	N/A	1,764	0	0	0	0	0
3014	STOR.	2	N/A	153	20	50	0	0	50
3016	OFFICE	4	N/A	1,359	6	145	0	145	0
3017	CHAPEL LOBBY	4	N/A	3,978	8	560	0	450	110
3018	CHAPEL	4	N/A	3,564	16	960	0	900	60
3019	ELEV. LOBBY	2	N/A	2,322	4	150	0	0	150
3020	WAIT	12	N	9,360	12	1,400	0	1,800	-400
3021	PHARM. PICK-UP	4	P	1,530	8	200	0	0	200
3022	PHARM.	4	P	6,750	7	740	0	600	140
3023	CORRIDOR	2	N/A	1,602	6	0	0	150	-150
3024	OFFICE	4	N/A	1,071	5	95	0	95	0
3025	SHELLED	2	N/A	3,249	8	410	0	410	0
3026	EXAM	6	N	1,548	12	230	0	305	-75
3027	EXAM	6	N	1,512	8	135	0	210	-75
3028	PAT. T.	10	N	468	17	50	0	130	-80
3029	CORRIDOR	2	N/A	1,359	7	150	0	0	150
3030	CORRIDOR	2	N/A	2,223	6	225	0	200	25
3031	STAFF T.	2	N	513	12	0	0	100	-100
3032	ISOLATION EXAM	12	N	1,503	17	250	0	425	-175
3033	PAT. T.	10	N	918	10	0	0	160	-160
3034	ANTE	10	P	360	17	100	0	0	100
3035	CORRIDOR	2	N/A	3,312	8	460	0	0	460
3036	ISOLATION EXAM	12	N	1,557	16	250	0	425	-175
3037	EQUIP.	2	N/A	1,485	5	125	0	125	0
3038	PAT. T.	10	N	513	12	0	0	100	-100
3039	EXAM	6	N	1,440	9	135	0	210	-75
3041	CORRIDOR	2	N/A	1,359	0	0	0	0	0
3042	ANTE	10	P	630	10	105	0	0	105
3043	ISOLATION EXAM	12	N	2,106	15	350	0	525	-175
3044	PAT. T.	10	N	504	15	50	0	130	-80
3045	STOR.	2	N/A	459	13	0	0	100	-100
3046	CORRIDOR	2	N/A	3,357	6	350	0	0	350
3047	EXAM	6	N	1,629	8	135	0	210	-75
3048	EXAM	6	N	1,359	9	135	0	210	-75
3049	EXAM	6	N	1,422	9	135	0	210	-75
3051	STOR.	2	N/A	495	10	0	0	80	-80
3052	CORRIDOR	2	N/A	2,799	4	170	0	0	170
3053	TRIAGE	12	N	1,314	13	125	0	275	-150
3054	WORK	4	N/A	477	33	265	0	0	265
3055	DIS.	4	N/A	684	9	100	0	0	100
3056	HALL	2	N/A	1,440	10	170	0	250	-80
3057	WORK	4	N/A	1,575	19	0	0	500	-500
3058	DIS.	4	N/A	684	9	100	0	0	100
3059	OFFICE	4	N/A	459	13	100	0	0	100
3061	TRIAGE	12	N	1,377	12	125	0	275	-150
3062	CORRIDOR	2	N/A	2,799	4	170	0	0	170
3065	EXAM	6	N	1,476	9	135	0	210	-75
3066	EXAM	6	N	1,494	10	175	0	250	-75
3067	EXAM	6	N	1,566	13	275	0	350	-75
3068	CORRIDOR/ALCOVE	2	N/A	1,125	6	120	0	0	120
3069	PHYS. WORK	4	P	1,152	13	250	0	0	250
3071	CORRIDOR	2	N/A	2,889	6	230	0	300	-70
3072	N.S.	4	P	1,395	13	250	0	300	-50
3073	EXAM	6	N	1,512	8	135	0	210	-75
3074	EXAM	6	N	1,503	10	175	0	250	-75
3075	PAT. T.	10	N	468	17	50	0	130	-80
3076	CORRIDOR	2	N/A	2,529	7	280	0	0	280
3077	EXAM	6	N	1,548	14	275	0	350	-75
3078	EXAM	6	N	1,512	8	135	0	210	-75
3079	N.S.	4	P	1,944	12	375	0	0	375
3081	CORRIDOR	2	N/A	3,294	5	255	0	200	55
3082	EXAM	6	N	1,566	8	135	0	210	-75
3083	CORRIDOR/ALCOVE	2	N/A	774	0	0	0	0	0
3084	HSKP.	10	N	684	9	0	0	100	-100
3085	SHELLED	2	N/A	9,603	3	500	0	500	0
3086	EXAM	6	N	1,476	9	135	0	210	-75
3087	EXAM	6	N	1,485	8	135	0	210	-75
3088	DINING	4	N	1,800	7	210	0	140	70
3089	KITCHEN	10	N/A	1,332	15	210	0	330	-120
3090	LOUNGE	4	N/A	2,079	6	210	0	0	210
3091	MAIL	4	N/A	603	7	75	0	0	75
3092	EXAM	6	N	1,521	8	135	0	210	-75
3093	CORRIDOR	2	N/A	2,295	8	300	0	0	300
3094	PAT. SH.	10	N	639	10	0	0	110	-110
3095	STAFF SH.	10	N	603	11	0	0	110	-110
3096	LOCKERS	10	N	1,179	15	100	0	300	-200
3097	HALL	0	N/A	675	0	0	0	0	0
3098	OFFICE	4	N/A	1,278	6	130	0	130	0
3099	EXAM	6	N	1,476	9	135	0	210	-75
3101	STAFF T.	10	N	486	10	0	0	80	-80
3102	OFFICE	4	N/A	864	6	90	0	90	0
3103	STOR.	4	N/A	756	9	110	0	110	0
3104	CORRIDOR	2	N/A	2,988	4	200	0	0	200
3105	ELEC.	0	N/A	2,040	7	225	0	225	0
3107	CORRIDOR	2	N/A	3,429	5	300	0	200	100
3108	PUB. T.	10	N	576	10	0	0	100	-100
3109	PUB. T.	10	N	576	10	0	0	100	-100
3111	ELEV. LOBBY	2	N/A	2,052	6	200	0	0	200
3112	STAFF T.	10	N	531	15	50	0	130	-80

ROOM AIR BALANCE - 3RD FLOOR (CONT)

ROOM NO.	ROOM NAME	REQ. AIR CHANGES (ACPH)	REQ. PRESSURE RELATIONSHIPS	VOLUME (CU FT)	ACT AIR CHANGES (ACPH)	AIR QUANTITIES			
						SUPPLY AIR (CFM)	RETURN AIR (CFM)	EXHAUST AIR (CFM)	PRESS AIR (CFM)
3113	OFFICE	4	N/A	819	18	250	0	250	0
3114	HALL	2	N/A	900	7	0	0	100	-100
3115	OFFICE	4	N/A	819	16	225	0	225	0
3116	CONTROL	4	P	378	13	80	0	0	80
3117	X-RAY	6	N/A	2,700	8	300	0	380	-80
3118	PAT. T.	10	N	450	11	0	0	80	-80
3119	CORRIDOR	2	N/A	2,574	7	200	0	300	-100
3121	EXAM	6	N	1,755	7	135	0	210	-75
3122	CORRIDOR	2	N/A	1,440	6	150	0	0	150
3123	EXAM	6	N	1,755	7	135	0	210	-75
3124	PAT. T.	10	N	531	15	50	0	130	-80
3125	N.S.	4	P	1,134	11	200	0	0	200
3126	CORRIDOR	2	N/A	4,815	4	300	0	250	50
3127	EXAM	6	N	1,755	7	135	0	210	-75
3128	EXAM	6	N	1,755	7	135	0	210	-75
3129	EXAM	6	N	2,043	6	170	0	210	-40
3131	EXAM	6	N	1,755	7	135	0	210	-75
3132	EXAM	6	N	1,755	7	135	0	210	-75
3133	CORRIDOR	2	N/A	1,440	6	150	0	0	150
3134	PAT. T.	10	N	531	15	50	0	130	-80
3135	EXAM	6	N	1,755	7	135	0	210	-75
3136	N.S.	4	P	1,539	12	300	0	0	300
3137	CORRIDOR	2	N/A	4,338	16	300	0	1,140	-840
3138	PHYS. WORK	4	P	1,098	11	200	0	0	200
3139	STOR.	2	N/A	3,429	5	305	0	305	0
3140	EXAM	6	N	1,755	7	135	0	210	-75
3141	AGVS SOILED	10	N	2,184	10	290	0	380	-90
3142	I.S.	4	N/A	1,064	0	0	0	0	0
3143	AGVS CLEAN	4	P	2,331	8	300	0	225	75
3144	MEDS	4	P	945	10	150	0	75	75
3145	HSKP.	10	N	567	11	0	0	100	-100
3146	CORRIDOR	2	N/A	1,881	6	200	0	200	0
3147	EXAM	6	N	1,368	9	135	0	210	-75
3148	EXAM	6	N	1,467	9	135	0	210	-75
3149	EXAM	6	N	1,476	9	135	0	210	-75
3150	CORRIDOR	2	N/A	1,377	7	150	0	0	150
3151	PAT. T.	10	N	567	11	0	0	100	-100
3152	LOW VOLTAGE	0	N/A	531	8	75	0	75	0
3153	MEDS	4	P	873	10	150	0	75	75
3165	SOUTH SKY BRIDGE	2	N/A	1,683	11	300	0	0	300
3167	NORTH SKY BRIDGE	2	N/A	1,683	11	300	0	0	300

ROOM AIR BALANCE - 4TH FLOOR

ROOM NO.	ROOM NAME	REQ. AIR CHANGES (ACPH)	REQ. PRESSURE RELATIONSHIPS	VOLUME (CU FT)	ACT AIR CHANGES (ACPH)	AIR QUANTITIES			
						SUPPLY AIR (CFM)	RETURN AIR (CFM)	EXHAUST AIR (CFM)	PRESS AIR (CFM)
4000	WAIT	4	N/A	2,340	19	150	750	0	-600
4001	RECEP.	4	N/A	1,620	4	120	0	0	120
4002	ADMIT.	4	N/A	1,620	9	240	0	0	240
4003	WAIT	4	N/A	3,591	13	500	790	0	-290
4004	PAT. T.	10	N	558	9	0	0	80	-80
4005	CORRIDOR	2	N/A	4,734	8	600	300	0	300
4006	BLOOD DRAW	6	P	3,420	6	350	250	0	100
4007	RESOURCE CENTER	4	N/A	5,670	8	775	775	0	0
4008	COUNSEL.	4	N/A	1,170	6	120	120	0	0
4009	COUNSEL.	4	N/A	1,287	6	120	120	0	0
4011	CORRIDOR	2	N/A	2,772	5	220	0	0	220
4012	PAT. T.	10	N	486	10	0	0	80	-80
4013	N.S.	4	P	1,800	9	280	0	0	280
4014	INFUSION	6	N/A	8,109	8	930	1,100	0	-170
4015	INFUSION	6	N/A	7,803	7	750	950	0	-200
4016	N.S.	4	P	1,800	9	280	0	0	280
4017	PAT. T.	10	N	486	10	0	0	80	-80
4018	COUNSEL.	4	N/A	1,107	7	120	120	0	0
4019	PAT. T.	10	N	486	10	0	0	80	-80
4021	N.S.	4	P	1,800	9	280	0	0	280
4022	INFUSION	6	N/A	7,920	7	750	950	0	-200
4023	PRIVATE INFUSION	6	P	1,062	6	110	110	0	0
4024	CORRIDOR	2	N/A	2,088	13	300	450	0	-150
4025	ELEC.	0	N/A	522	26	225	225	0	0
4026	STAIR LOBBY	2	N/A	1,566	4	100	0	0	100
4027	PAT. T.	10	N	504	10	0	0	80	-80
4028	N.S.	4	P	1,800	9	280	260	0	20
4029	INFUSION	6	N/A	6,210	6	660	500	0	160
4031	PRIVATE INFUSION	6	N/A	1,107	6	110	110	0	0
4032	STOR.	0	N/A	450	0	0	0	0	0
4033	PAT. T.	10	N	504	10	0	0	80	-80
4034	N.S.	4	P	1,800	9	280	260	0	20
4035	INFUSION	6	N/A	6,210	6	660	500	0	160
4036	PRIVATE INFUSION	6	P	1,035	6	110	110	0	0
4037	PAT. T.	10	N	504	10	0	0	80	-80
4038	STOR.	0	N/A	450	0	0	0	0	0
4039	CORRIDOR	2	N/A	4,392	10	350	750	0	-400
4039B	CORRIDOR	3	N/A	3,096	5	250	0	0	250
4041	PHARM. WORK	4	P	2,772	7	320	0	270	50
4042	PHARM. ANTE	30	P	1,800	34	1,020	0	900	120
4043	PHARM. CLEAN	30	P	1,233	39	800	0	600	200
4044	PHARM. CHEMO	30	N	1,791	34	800	0	1,020	-220
4045	WAIT	4	N/A	1,899	9	300	0	0	300
4046	QUIET / COUNSEL.	4	N/A	1,395	6	145	145	0	0
4047	ALCOVE	0	N/A	180	0	0	0	0	0
4048	SCALE	0	N/A	180	0	0	0	0	0
4049	CORRIDOR	2	N/A	2,772	18	300	820	0	-520