



2ND FLOOR PLAN - K WING REMODEL - PLUMBING
SCALE: 1/8"=1'-0"

GENERAL NOTES:

1. CAP EXISTING DOMESTIC WATER PIPING AT VALVES TO WHERE PIPING HAS BEEN DEMOLISHED.

KEY NOTES:

- ① 4"W DOWN.
② 2"W DOWN.
③ 2"W DOWN.
④ 1/2"LLCW IN WALL TO P10. MOUNT P10 18" ABOVE FINISHED FLOOR AT BACK OF CASEWORK. PROVIDE 1/2" MAKE WATER CONNECTION TO COFFEE MAKER 129.
⑤ 1/2"LLCW AND 1" COPPER DRAIN IN WALL TO P11. MOUNT P11 18" ABOVE FINISHED FLOOR AT BACK OF CASEWORK.
⑥ PROVIDE WATER AND INDIRECT DRAIN CONNECTIONS TO ICE MACHINE 127 FROM P11.
⑦ PROVIDE 2" STANDPIPE AND MECHANICAL TRAP PRIMER IN CASEWORK FOR ICE MACHINE DRAIN. SEE DETAIL 7 ON M10.05.
⑧ 1/2"HWC DOWN TO HOT WATER CONNECTION AT MIXING VALVE.
⑨ RUN 2"W HORIZONTAL IN WALL TO AVOID ELECTRICAL EQUIPMENT ON LEVEL 1. CONNECT TO 4"W BEHIND TOILET ROOM 2292.
⑩ WALL HYDRANT ZURN Z1325-VB, 3/4" HOSE CONNECTION, MOUNT ACCESSIBLE FROM THE EXTERIOR, 42" ABOVE FINISHED GRADE.
⑪ PROVIDE P4E SIMILAR TO TRAUMA FIXTURE FAUCET AND CONTROL.