



### 3RD FLOOR PLAN - SOUTH - HVAC PIPING

GENERAL NOTES:

1. TERMINAL UNITS SHALL BE PIPED WITH TWO-WAY CONTROL VALVES UNLESS NOTED OTHERWISE ON PLANS. SEE DETAIL 1 ON M10.05.

KEY NOTES:

- ① PIPE TERMINAL UNIT HEATING COIL WITH THREE-WAY CONTROL VALVE, SEE DETAIL 1 ON M10.05.

