


4TH FLOOR PLAN - SOUTH - HVAC PIPING  
SCALE: 1/8"=1'-0"

GENERAL NOTES:  
1. TERMINAL UNITS SHALL BE PIPED WITH TWO-WAY CONTROL VALVES UNLESS NOTED OTHERWISE ON PLANS. SEE DETAIL 1 ON M10.05.

KEY NOTES:  
① PIPE TERMINAL UNIT HEATING COIL WITH THREE-WAY CONTROL VALVE, SEE DETAIL 1 ON M10.05.




GIFFIN • BOLTE • JURGENS  
ARCHITECTS

815 S.W. SECOND AVENUE • PORTLAND, OREGON 97204  
(503) 223-0992 • www.gbjarch.com FAX (503) 294-3961

CDI ENGINEERS

4200 - 184th St SW, Suite 200  
Lynnwood, WA 98036  
T 425.872.1071 F 425.778.8769  
www.CDIENGINEERS.com



MultiCare

EMERGENCY DEPARTMENT & CANCER CENTER EXPANSION

TACOMA, WASHINGTON

Date 09-26-2008  
Scale 1/8"=1'-0"  
Drawn By CDI  
Job No. 4034

4TH FLOOR  
PLAN - SOUTH -  
HVAC PIPING

M5  
04