



7TH FLOOR PLAN - NORTH - FIRE PROTECTION
SCALE: 1/8"=1'-0"

- KEY NOTES:**
- ① COMBINATION STAND PIPE.
 - ② 2" TEST DRAIN.
 - ③ PROVIDE SPRINKLER ZONE VALVE ASSEMBLY AND HOSE VALVE IN RECESSED CABINET AT MID STAIR LANDING.

