



1. SEE ARCHITECTURAL PLANS, SECTIONS AND ELEVATIONS FOR EXACT EQUIPMENT AND DEVICE LOCATIONS, INCLUDING MOUNTING HEIGHTS.
2. PROVIDE RED DEVICES AND COVERPLATES FOR DEVICES SERVED FROM EMERGENCY POWER SYSTEM.
3. SEE ARCHITECTURAL PLANS FOR LOCATIONS OF SOUND, SMOKE AND FIRE RATED WALLS.
4. ABOVE COUNTER RECEPTACLES LOCATED WITHIN 5' OF SINK SHALL BE GFI RATED.
5. SEE MECHANICAL DRAWINGS FOR EXACT LOCATION OF MECHANICAL EQUIPMENT. COORDINATE WITH MECHANICAL CONTRACTOR PRIOR TO ROUGH-IN.

- ▶ ALL CHANGES WITHIN K-MING SHALL BE FED FROM THIS ELECTRICAL ROOM.
- ▶ BLANKET WARMER CONNECTION.
- ▶ PROVIDE HARD WIRED CONNECTION TO PNEUMATIC TUBE SYSTEM DIVERTER. CONFIRM EXACT LOCATION WITH VENDOR SHOP DRAWINGS PRIOR TO ROUGH IN.
- ▶ UNDER COUNTER REFRIGERATOR CONNECTION.
- ▶ REFRIGERATOR CONNECTION.
- ▶ ICE MACHINE CONNECTION.
- ▶ PYXIS CONNECTION.
- ▶ MICROWAVE CONNECTION.
- ▶ COFFEE MACHINE CONNECTION.
- ▶ PROVIDE HARD WIRED CONNECTION TO AUTO-SINK SENSOR.
- ▶ PROVIDE HARD WIRED CONNECTION TO AUTO-DOOR. PROVIDE ALL CONDUIT AND WIRING FOR DOOR CONTROL. CONFIRM REQUIREMENT WITH DOOR HARDWARE SCHEDULE PRIOR TO ROUGH IN.
- ▶ HAND DRYER CONNECTION.
- ▶ PROVIDE CIRCUITS AS SHOWN TO 4 DOUBLE DUPLEX RECEPTACLES MOUNTED IN CABLE TRAY RACK.
- ▶ REPLACE RECEPTACLE INTO EXISTING CIRCUIT.
- ▶ RECONNECT AUTO-DOOR INTO EXISTING AUTO-DOOR CIRCUIT.
- ▶ PROVIDE HARD WIRED CONNECTION TO BARIATRIC LIFT. CONFIRM EXACT LOCATION WITH ARCHITECT PRIOR TO ROUGH IN.

0 4 8 16 24
as indicated feet