

1 2 3 4 5 6 7

A

DETAIL 1 FLAG NOTES:


- REFER TO DETAIL FOR TYPICAL TRANSFORMER GROUNDING DETAIL.
- ALL GROUNDING ELECTRODE CONDUCTOR CONNECTIONS SHALL USE COMPRESSION LUGS, TYPICAL.
- SPACE GROUND RODS AT 25' ON CENTER.
- REFER TO DETAIL 4/E8.00 FOR MASTER GROUND BAR TYPICAL DETAIL.
- REFER TO DETAIL 7/E8.01 FOR TYPICAL GROUND BAR DETAIL. BOND ALL GROUND BARS TO NEAREST BUILDING STEEL WITH #4/0 TINNED COPPER.
- PROVIDE GROUND WELL IN ELECTRICAL ROOM AS NOTED. SEE DETAIL 8/E8.01.

B

C

D


E



1 ONE-LINE / RISER DIAGRAM - GROUNDING
E6.04 SCALE: NONE



GIFFIN • BOLTE • JURGENS
ARCHITECTS
815 S.W. SECOND AVENUE, PORTLAND, OREGON 97204
(503) 223-0992 www.gbjarch.com FAX (503) 594-3961



MultiCare
EMERGENCY DEPARTMENT & CANCER CENTER EXPANSION
TACOMA, WASHINGTON

| | |
|----------|------------|
| Date | 09-26-2008 |
| Scale | NONE |
| Drawn By | JL |
| Job No. | 4034 |

ONE-LINE
RISER DIAGRAM
GROUNDING

E6
04

N:\B13608\CADD-05\604_E6-04.DWG SEP 25, 2008 -- 11:34:51 AM BY: TWITE