



Notes:

- Symbol number indicates feeder rating.
- Feeders with no letter suffix after the number are 3-phase, 4-wire with ground conductor.
- Feeders with letter suffix after the number are as follows:
 - H: Half size neutral.
 - N: No neutral.
 - D: Double or oversized neutral conductor.
 - S: Single Phase
 - MI: Mineral Insulated
- Install bundled single conductor Type MI cables in ladder tray. Install per manufacturer's instructions to provide a 2-hour fire resistance rating.
- Terminate cables at source and load using manufacturer's termination fittings and B&W THHN/THWN cable.

1. THIS DRAWING PROVIDED FOR REFERENCE ONLY.