



- GENERAL NOTES:**
- CONTRACTOR TO PROVIDE AND INSTALL DUKE ENERGY UNDERGROUND PRIMARY CONDUIT AND REQUIRED PULL BOXES. COORDINATE WITH DUKE ENERGY FOR ENGINEERED LAYOUT AND DESIGN OF PRIMARY CONDUIT SYSTEM.
  - COORDINATE WITH DUKE ENERGY FOR INSTALLED DEPTH OF BELOW GRADE CONDUITS.
  - ALL CONDUITS SHALL BE 4" SCHEDULE 40 PVC GRAY IN COLOR AND MEET UL REQUIREMENTS.
  - INSTALL DUKE ENERGY PROVIDED LOCATOR MARKER BALLS AND END CAPS.
  - INSTALL CONCRETE ON 4" CONDUIT 90 DEGREE BENDS.
  - AFTER INSTALLATION CONTRACTOR MUST MANHOLE ALL CONDUIT.
  - CONTRACTOR MUST PROVIDE PULL STRING IN ALL CONDUITS NO MATTER THE CONDUIT LENGTH. COORDINATE WITH DUKE ENERGY REQUIREMENTS.
  - CONTRACTOR SHALL COORDINATE WITH DUKE ENERGY FOR MINIMUM RADIUS OF 90 DEGREE BENDS ON 4" CONDUITS.
  - ALL CONTRACTOR INSTALLED CONDUIT MUST BE INSPECTED BY A DUKE ENERGY INSPECTOR BEFORE THE TRENCH IS COMPLETELY BACKFILLED.

- KEY NOTES:**
- PROVIDE (1) 2" EMPTY CONDUIT WITH PULL LINE FOR CITY OF ST. PETERSBURG DATA LINE. PROVIDE IN-GRADE PULL BOXES AS REQUIRED.
  - PROVIDE (2) 2" EMPTY CONDUITS WITH PULL LINES FOR CONTINUATION OF PIER TEAM'S DATA LINES. PROVIDE IN-GRADE PULL BOXES AS REQUIRED.

