RFI 1371 per RFI 1371, mount pyxis stations 16108, 16125, 16131, 16133, 16134 and 16152 at 86" AFF 

© 2009 Equipment Collaborative, Inc. All rights reserved. No part of this document may be reproduced or utilized in any form without prior written authorization of Equipment Collaborative, Inc.

Ceiling Line

To Headwall Feeding Junction Box EACH PROVISION IS PROVIDED WITH ONE DIA. GROMMETED PASSTHRU DESCRIPTION
DUPLEX PEDS 20A RED
FACEPLATE ENGRAVING
J-BOX, INTEGRIS 2001B & 2002B PROVISION, 1GANG W/FACEPLATE
GAS MANIFOLD RIGHT HAND U MEDICAL AIR MEDICAL OXYGEN MEDICAL VACUUM BASKET 21 3/8W X 2 7/8D X 4 5/16"H(ABOVE RAIL)
UTILITY SHELF 20 3/8"W X 12 1/8"D 50LBS LOAD
BOTTLE SLIDE STANDARD 1 3/16" INNER WIDTH ALL RECEPTACLES TO BE PEDIATRIC TYPE. GROUND PINS MOUNTED UP WHERE APPLICABLE. TOTAL UNIT ON CRITICAL BRANCH RECEPTACLES TO HAVE RED FACEPLATES. ALL RECEPTACLES FACEPLATES TO BE MARKED (SEE CIRCUIT SCHEDULE) Floor Line 10½ 27 3'-3½" A5 Typical Headwall

A. Refer to Equipment Book for additional information. B. Refer to Architectural Drawings for toilet accessories types and locations (CFCI). C. Unless otherwise noted, refer to Q0.00 for typical equipment mounting heights. D. Not used. E. The contractor shall verify and coordinate clear dimensions required for owner furnished equipment that is located within or adjacent to any piece of casework. RFI 5766 F. The contractor shall supply blocking for wall / ceiling mounting of equipment unless mounting support is otherwise furnished as part of the equipment. Space for vending machine: Refer to architectural drawings for additional information. H. Not used.

OF/CI — Owner Furnished / Contractor Installed Owner Furnished / Owner Installed Owner Furnished / Vendor Installed Contractor Furnished / Contractor Installed Not In Contract

(A1) Plan Symbols Legend

Equipment Item Number

Equipment Note to Sheet


Indicates Movable Equipment (ASE)

Indicates Fixed Equipment

Revision Symbol



ARCHITECT OF RECORD Paul C. Gloriod





REVIEWED IN ACCORDANCE WITH THE REQUIREMENTS OF 124, CCR

CHILDREN'S HOSPITAL OF ORANGE COUNTY 455 S. Main St. Orange, CA 92868-3874

TOWER II

PROJECT NUMBER 12011.00 Increment #7, Vol. 2E

OSHPD - PROJECT NUMBER IL 072072-30

**OSHPD** Permit

01/27/2010

DRAWING TITLE **EQUIPMENT GENERAL** NOTES & INFO

DRAWING NUMBER

Q0.02