

ROOM AIR BALANCE TABLE - PANCAKE LOWER LEVEL - STERILIZER

ROOM NUMBER/NAME	ROOM AREA (FT.) ²	CEILING HEIGHT (FT.)	CMC		PRESSURE +/-	OSA AC/HR	SUPPLY CFM	RETURN CFM	EXHAUST CFM	INFILTRATION CFM	EXFILTRATION CFM
			AC/HR.	REQUIRED SUPPLY AC/HR.							
B.004.00.J Staff Interchange	113	9	10	170	E	4	200	0	200	0	0
B.004.00.K Housekeeping	79	9	10	119	N	4	150	0	200	50	0
B.004.00.L Storage Detergent	99	9	10	149	N	3	150	0	200	50	0
B.004.00A Sterilizers, B.004.00B Loading, B.004.00C Sterile Supply, B.004.00D Sterile Instruments, B.004.00E Prep & Pack, B.004.00G Case Care Holding, B.004.00H Future Cart Wash Automatic, B.004.00I Cart Wash and B.004.00N Decontamination Area.	4643	9	10	6,965	N	4	10,000	0	10,400	500	100
B.004.03 Toilet/ Lockers Female	232	9	10	348	N	3	350	0	450	100	0
B.004.01 Staff Lounge	185	9	10	278	E	3	300	0	100	0	200
B.004.02 Toilet/ Lockers Male	230	9	10	345	N	3	350	0	450	100	0
B.004 Receiving & Break-Out	183	9	4	110	P	2	200	0	0	100	300

ROOM AIR BALANCE TABLE - TOWER II - LOWER LEVEL

ROOM NUMBER/NAME	ROOM AREA (FT.) ²	CEILING HEIGHT (FT.)	CMC		PRESSURE +/-	OSA AC/HR	SUPPLY CFM	RETURN CFM	EXHAUST CFM	INFILTRATION CFM	EXFILTRATION CFM
			AC/HR.	REQUIRED SUPPLY AC/HR.							
B-071.00.C Corridor	400	9	4	240	E	2	400	0	250	0	150
B-072.00.C Corridor	560	9	4	336	E	2	400	0	400	0	0
B-116.00.C Corridor	500	9	4	300	E	2	400	150	0	0	250
B-2.008.00.L Staff Elev. Lobby	399	9	4	239	E	3	500	0	500	0	0
B-000.00.L Public Elev. Lobby	399	9	4	239	E	3	500	0	500	0	0
B-071.05 Oncall Room	101	9	4	61	E	3	150	150	0	0	0
B-071.03 Oncall Room	101	9	4	61	E	3	150	150	0	0	0
B-071.01 Oncall Room	101	9	4	61	E	3	150	150	0	0	0
B-1000 P Tube Equipment	203	9	4	122	E	3	300	0	300	0	0
B-071.06 Toilet Shower	77	9	10	116	N	3	100	0	175	75	0
B-071.04 Toilet Shower	82	9	10	123	N	3	100	0	175	75	0
B-071.07 Storage Transport Equipment	378	9	4	226	E	2	400	400	0	0	0
B-071.02 Break Room	135	9	4	81	E	5	300	0	300	0	0
B-072.12 Phys. On Call	108	9	4	65	E	3	150	150	0	0	0
B-072.08 Phys. On Call Hall	91	9	4	55	N	3	100	0	0	0	100
B-072.11 Phys. On Call	108	9	4	65	E	3	150	150	0	0	0
B-072.09 Phys. On Call	117	9	4	70	E	3	150	150	0	0	0
B-072.10 Toilet Shower	73	9	10	110	E	2	75	0	175	100	0
B-072.07 Phys. On Call	171	9	4	103	E	2	150	0	150	0	0
B-072.04 Phys. On Call Hall	66	9	4	40	E	4	100	0	50	0	50
B-072.05 Phys. On Call	104	9	4	62	E	3	150	0	150	0	0
B-072.03 Phys. On Call	111	9	4	67	E	3	150	0	150	0	0
B-072.00 Phys. On Call Hall	68	9	4	41	E	3	100	0	50	0	50
B-072.01 Phys. On Call	105	9	4	63	E	3	150	0	150	0	0
B-072.02 Toilet Shower	68	9	10	102	N	3	100	0	150	50	0
B-072.06 Toilet Shower	68	9	10	102	N	3	100	0	150	50	0
B-088.00.C Corridor	1070	9	4	642	E	3	1,200	1200	0	0	0
B-084 Fire Pumps	715	9	4	429	E	1	400	400	0	0	0
B-086 Main Electrical	820	9	4	492	E	1	400	400	0	0	0
B-088 Normal Electrical	2145	9	4	1,287	E	1	1,100	1100	0	0	0
B-090 Emergency electrical	1360	9	6	1,224	E	1	700	700	0	0	0
B-102 Storage	67	9	6	60	E	3	100	0	100	0	0
B-104 Building Control System	153	9	6	138	E	2	400	0	400	0	0
B-105 Toilet	54	9	6	49	N	4	100	0	175	75	0
B-106 Mechanical	710	9	4	426	E	2	600	0	600	0	0
B-110 Mechanical	3420	9	2	1,026	E	1	1,700	1700	0	0	0
B-110A Office	223	9	10	335	E	3	300	300	0	0	0
B-112.00A Linen/Traeh	400	9	10	600	N	3	600	0	700	100	0
B-112 Trash chute Holding	215	9	10	323	N	2	300	0	350	50	0
B.003 Lab Staff Lounge	237	9	4	142	E	4	400	0	500	100	0

ROOM AIR BALANCE TABLE - PANCAKE - LOWER LEVEL

ROOM NUMBER/NAME	ROOM AREA (FT.) ²	CEILING HEIGHT (FT.)	CMC		PRESSURE +/-	OSA AC/HR	SUPPLY CFM	RETURN CFM	EXHAUST CFM	INFILTRATION CFM	EXFILTRATION CFM
			AC/HR.	REQUIRED SUPPLY AC/HR.							
B.030 Elec. Room	136	9	4	82	E	15	1,000	1000	0	0	0
B.028 IS Room	145	9	4	87	E	17	1,250	1250	0	0	0
B.034 Storage Child Life	103	9	2	31	E	2	100	100	0	0	0
B.036.01 Storage J.I.T. Plant Opps	296	9	2	89	E	2	300	300	0	0	0
B.040.01 Officer Volunteer Dir	162	9	4	97	E	2	200	200	0	0	0
B.040.02A, B & C Coord	501	9	4	301	E	2	500	500	0	0	0
B.040.02 Storage	129	9	2	39	E	2	150	150	0	0	0
B.040.03 Val Lounge/ Workroom	235	9	3	106	E	3	400	0	400	0	0
B.040.04 call center	186	9	4	118	E	5	500	500	0	0	0
B.028.00.C Corridor	332	9	4	199	E	1	200	0	0	0	200
B.004.06 Conference Room	148	6	4	59	E	5	250	250	0	0	0
B.004.07 Office Manager	116	2	4	15	E	16	200	200	0	0	0
B.004.05 Wait, B.004.05A Asst, B.004.05, B workstation, B.004.05 Instrument Cord, B.004.05 Copy Fax printer	500	9	4	300	E	2	600	600	0	0	0
B.004.05A Toilet Staff Male	66	9	10	99	N	3	100	0	175	75	0
B.035 Command Center Server	75	9	4	45	E	8	300	300	0	0	0
B.003.00.C Corridor	1000	9	4	600	E	2	800	125	0	0	675
B.022 Elevator Machine Room	114	9	2	34	E	4	200	0	200	0	0
B.002 Telephone Switch Gear	975	9	4	585	E	4	2,000	2000	0	0	0
B.036.02 Office MGR.	142	9	4	85	E	3	200	200	0	0	0
B.036.03A Office Asst, B.036.03 PBX & B.036.03B Alcove Beverage	409	9	4	245	E	3	600	525	0	0	75
B.036.04 Office Supervisor	101	9	4	61	E	4	200	200	0	0	0
B.036.05 Toilet Staff	84	9	10	126	E	2	75	0	175	100	0
B.036.06 Building Command Center	318	9	4	190	E	5	800	800	0	0	0
B.048.00.V Elevator Vestibule	123	9	4	74	E	2	150	0	150	0	0
B.048.01 elevator Equipment	55	9	4	33	E	5	150	0	150	0	0
B.050 Elec. Room	146	9	4	88	E	14	1,000	0	1,000	0	0
B.007.00.C Corridor	1564	9	4	938	E	1	1,000	900	200	200	100
B.007.06 Teaching Rm	107	9	4	64	E	3	150	150	0	0	0
B.007.08 Copy/ Work Room	107	9	4	64	E	4	200	200	0	0	0
B.007.10 Off. Lab Comp. Syst. Coord.	97	9	4	58	E	4	200	200	0	0	0
B.007.12 Office Ancillary Testing	105	9	4	63	E	3	150	150	0	0	0
B.007.14 Office Pathology	105	9	4	63	E	3	150	150	0	0	0
B.007.16 Office Chief Path	111	9	4	67	E	3	150	150	0	0	0
B.007.16A Reception, B.007.16B Assistant, B.007.13A Assistant, B.007.015A Assistant and B.007.06C Corridor	900	9	4	540	E	2	1,000	1000	0	0	0
B.007.07 Conference	319	9	4	191	E	4	600	600	0	0	0
B.008.00.A Corridor	178	9	4	107	E	3	300	0	0	0	300
B.007.13 Office MD Path	92	9	4	55	E	3	150	150	0	0	0
B.007.15 Office MD Path	90	9	4	54	E	3	150	150	0	0	0
B.064.00.C Corridor	1073	9	2	322	E	2	975	0	0	0	975
B.007.30 EVS	271	9	10	407	N	4	600	0	700	100	0
B.007.28 Toilet/ Lockers Lab Staff	364	9	10	546	N	3	600	0	700	100	0
B.062 IS Room	143	9	11	236	E	17	1,250	0	1,250	0	0
B.064 ELEC Room	117	9	12	211	E	17	1,000	0	1,000	0	0
B.067 Housekeeping	57	9	10	86	N	4	100	0	175	75	0
B.007.24 Toilet/ Lockers Lab Staff	193	9	10	290	N	3	300	0	400	100	0
B.002.00.C Corridor & B.002.00.A & Alcove Waiting	557	9	4	334	E	2	500	0	250	0	250

ROOM AIR BALANCE TABLE - PANCAKE LOWER LEVEL - PATHOLOGY LAB.

ROOM NUMBER/NAME	ROOM AREA (FT.) ²	CEILING HEIGHT (FT.)	CMC		PRESSURE +/-	OSA AC/HR	SUPPLY CFM	RETURN CFM	EXHAUST CFM	INFILTRATION CFM	EXFILTRATION CFM
			AC/HR.	REQUIRED SUPPLY AC/HR.							
B.008.04 Shower & Locker Staff	165	9	10	248	N	2	150	0	250	100	0
B.008.03A Ante Room	81	9	12	146	P	5	200	0	0	0	200
B.008.03 Autopsy	385	9	12	693	N	8	1,500	0	1,700	200	0
B.008.02 Body Holding	264	9	12	475	E	4	500	0	650	250	100
B.008.01 Family Room	176	9	6	158	E	3	250	0	150	0	100
B.008.05 Histology Supervisor	81	9	4	49	P	4	150	0	75	0	75
B.008.06 Processor Room	161	9	12	290	N	6	500	0	600	100	0
B.008.00 Histology, B.008.07 Reagent Prep and B.008.08 Specimen Receiving	1685	9	12	3,033	E	4	3,400	0	3,525	325	200
B.010 Storage	634	9	4	380	P	6	2,000	0	1,350	0	650
B.010.01 Dark Room IFA	98	9	10	147	N	4	200	0	300	100	0
B.009.01 Reagent Prep	77	9	12	139	P	13	500	0	400	0	100
B.009.02 Amplification	215	9	12	387	N	8	900	0	1,100	200	0
B.009.03 Detection	132	9	12	238	N	12	800	0	900	150	50
B.009.04 Electro Phoresis	70	9	12	126	E	9	300	0	300	0	0
B.009.05 Clean Room PaperWork	83	9	12	149	P	10	400	0	300	0	100
B.009 Molecular B.009.06 Sample Receiving and B.009.07 Specimen Prep.	668	9	12	1,202	N	7	2,300	0	2,500	500	300
B.011.01 Microbiology Molecular Supervisor	105	9	6	95	P	4	200	0	100	0	100
B.011.02 Virology	414	9	12	745	N	7	1,500	0	1,600	100	0
B.011 Microbiology	1342	9	12	2,416	N	5	3,500	0	3,900	650	250
B.011.03 Mycology	223	9	12	401	N	13	1,500	0	1,650	150	0