


GENERAL NOTES:
1. REFER TO ARCHITECTURAL PLANS AND ELEVATIONS FOR COORDINATION OF EXACT LOCATION AND MOUNTING HEIGHTS OF LUMINAIRES AND ELECTRICAL DEVICES.
KEY NOTES:
1. MOUNT POWER SUPPLY FOR STANWELL LIGHTING IN CEILING SPACE BELOW ROUTE 1'S CONDUIT IN THE SLAB. STUB CONDUIT INTO HANDRAIL AND CONNECT TO HANDRAIL LIGHTING. CIRCUIT TO TEHA. FIXTURES ARE PHOTOCELL CONTROLLED. ROUTE CIRCUIT THROUGH PHOTOCELL CONTACTOR LOCATED IN THE MAIN ELECTRICAL ROOM.
2. HANDRAIL WITH INTEGRAL HIGH OUTPUT LED LIGHT FIXTURE PER ARCHITECTURAL PLANS AND DETAILS.


ISSUED FOR	DATE
Pre-Schematic Design	07/14/2008
Schematic Design	07/28/2008
BID PK #1	10/06/2008
SOL Progress	10/24/2008
BID PK #1 80 CD	12/01/2008
BID PK #1 100 CD	02/16/2009
BID PK #2 100 CD	03/26/2009
100% CD	05/08/2009
CD 4	01/07/2010
CD 1	02/26/2010
CD 2	02/28/2010
CD 3	04/15/2010

SANFORD CONSORTIUM FOR REGENERATIVE MEDICINE
2880 TORREY PINES SCENIC DRIVE
LA JOLLA, CALIFORNIA 92037



CONSULTANT
Lanford/Phelps Consortium LLC
100 West Broadway, Suite 1000, San Diego, CA 92101
(619) 592-8888

FENTRESS ARCHITECTS
401 Broadway, Suite 1000, San Diego, CA 92101
(619) 592-8888



SHEET NAME
PARTIAL LIGHTING FIRST FLOOR PLAN - ZONE 1
DRAWN BY: Author
PROJECT #: 200725.000
SHEET NUMBER

E2211

U.C.S.D.
PRELIMINARY DRAWINGS
PROGRESS DRAWINGS
REVIEW DRAWINGS
CONSTRUCTION DRAWINGS

SCALE
1/4" = 1'-0"

PARTIAL LIGHTING FIRST FLOOR PLAN - ZONE 1

FOR CONTINUATION SEE SHEET E2212

1/22/2008 4:52:10 PM
File Path
C:\Users\j...
j...
j...

Warning: It is a violation of the law for any person, unless acting under the direction of a licensed architect, to alter an item in any way. If an item in this document is altered, the altering architect, if other than the architect of record, shall affix the item his seal and the notation "altered by" followed by his signature and the date of such alteration, and the specific description of the alteration.