



FOR CONTINUATION SEE SHEET E2242

SCALE	
1/4" = 1'-0"	

E2241

GENERAL NOTES:

1. REFER TO ARCHITECTURAL PLANS AND ELEVATIONS FOR COORDINATION OF EXACT LOCATION AND MOUNTING HEIGHTS OF LUMINAIRES AND ELECTRICAL DEVICES.
2. CIRCUIT ALL NORMAL LIGHTING TO PANEL 4HA.
CIRCUIT ALL OPTIONAL, STANDBY LIGHTING TO 15H.
CIRCUIT ALL EMERGENCY LIGHTING TO 15HA.

KEY NOTES:

1. MOUNT POWER SUPPLY FOR STEARWELL LIGHTING IN CEILING SPACE BELOW ROUTE 17C.
CONDUIT IN THE SLAB, STUD CONDUIT INTO HANDRAIL AND CONNECT TO HANDRAIL LIGHTING. CIRCUIT TO 1EHA.
FIXTURES ARE PHOTOCELL CONTROLLED.
ROUTE CIRCUIT THROUGH PHOTOCELL CONTROLLER LOCATED IN THE MAIN ELECTRICAL ROOM.
2. HANDRAIL WITH INTEGRAL, HIGH OUTPUT LED LIGHT FIXTURE PER ARCHITECTURAL PLANS AND DETAILS.