

- GENERAL NOTES:**
1. MOUNT ELECTRICAL DEVICES IN LER AT 42" AFF.
  2. REFERENCE EQUIPMENT CONNECTION SCHEDULE ON SHEET E3000 FOR EQUIPMENT INFORMATION.
- KEY NOTES:**
1. STUB OUT TO CABLE TRAY, ROUTE 1" C. TIGHT TO SLAB, TYP. FOR EQUIPMENT SPACE.
  2. CIRCUIT E16, HIGH TEMP OVER, TO 11D AND CONNECT TO OVER PER MANUFACTURER'S REQUIREMENTS.
  3. CONNECT TO SYSTEMS FURNITURE.
  4. CONNECT TO HAND DRYER.
  5. CONNECT TO DRINKING FOUNTAINS.
  6. NEMA 6-30R, PROVIDE 2#10, 1#10 GND.
  7. NEMA 6-20R.
  8. CONNECT TO FUME HOOD.
  9. CONNECT TO MOTORIZED SHADES.
  10. NOT USED.
  11. PROVIDE NEMA 3R DEVICES IN THIS ROOM.
  12. CONNECT TO DOOR SECURITY XMR.
  13. CONNECT TO FIRE ALARM CONTROL PANEL.
  14. CONNECT TO RESCUE ASSISTANCE POWER SUPPLY.
  15. PROVIDE A 5-20R RECEPTACLE IN SURFACE RACEWAY FOR CONNECTION TO EQUIPMENT.
  16. DISCONNECT FOR TRASH COMPACTOR.
  17. CONNECT TO BMS CONTROLS. COORDINATE EXACT LOCATION WITH CONTROLS CONTRACTOR.


**SANFORD CONSORTIUM FOR REGENERATIVE MEDICINE**

2880 TORREY PINES SCENIC DRIVE  
LA JOLLA, CALIFORNIA 92037



**CONSULTANT**  
Lankford/Phelps Consortium LLC  
3000 Torrey Pines Road, Suite 100  
La Jolla, CA 92037  
TEL: 858.592.1234 FAX: 858.592.1235  
WWW.LANKFORDPHELPS.COM

**FENTRESS ARCHITECTS**  
401 Broadway, Denver, CO 80202  
303.733.0000  
WWW.FENTRESSARCHITECTS.COM



**STAMP**  
SHEET NAME  
PARTIAL POWER FIRST FLOOR  
PLAN - ZONE 2  
DRAWN BY: Author  
PROJECT #: 200725.000  
SHEET NUMBER

**E3212**

SCALE  
1/4" = 1'-0"

1

PARTIAL POWER FIRST FLOOR PLAN - ZONE 2

10/20/2008 4:22:10 PM  
F:\E3212.dwg  
F:\E3212

Warning: It is a violation of the law for any person, unless acting under the direction of a licensed architect, to alter an item in any way. If an item in this document is altered, the altering architect, if other than the architect of record, shall affix the item his seal and the notation "altered by" followed by his signature and the date of such alteration, and the specific description of the alteration.