

PANEL: BLPA VOLT : 208Y120V 3 PHASE, 4 WIRE BUS : 225 AMP MAIN : 150A, 3P FED FROM : BOB														
SURFACE MOUNTED 10 KAIC RATING NEMA 1 ENCLOSURE														
DESCRIPTION	W	U	W	U	W	U	W	U	W	U	W	U	W	U
HOLDING RECEPT.	1	1560	20	1	3120	20	1	3120	20	1	1560	20	1	3120
PROC BSC	3	1764	20	1	3528	20	1	3528	20	1	1764	20	1	3528
PROC DED RECEPT.	5	180	1R	20	1	360	1R	20	1	180	8	1	360	8
HOLDING RECEPT.	7	1560	20	1	3120	20	1	3120	20	1	1560	8	1	3120
PROC BSC	9	1764	20	1	3528	20	1	3528	20	1	1764	10	1	3528
PROC DED RECEPT.	11	180	1R	20	1	360	1R	20	1	180	12	1	360	12
HOLDING RECEPT.	13	1560	20	1	3120	20	1	3120	20	1	1560	14	1	3120
PROC BSC	15	1764	20	1	3528	20	1	3528	20	1	1764	16	1	3528
PROC DED RECEPT.	17	180	1R	20	1	360	1R	20	1	180	18	1	360	18
HOLDING RECEPT.	19	1560	20	1	3120	20	1	3120	20	1	1560	20	1	3120
PROC BSC	21	1764	20	1	3528	20	1	3528	20	1	1764	22	1	3528
PROC DED RECEPT.	23	180	1R	20	1	360	1R	20	1	180	24	1	360	24
HOLDING RECEPT.	25	1560	20	1	3120	20	1	3120	20	1	1560	26	1	3120
PROC DED RECEPT.	27	1764	20	1	3528	20	1	3528	20	1	1764	28	1	3528
PROC DED RECEPT.	29	180	1R	20	1	360	1R	20	1	180	30	1	360	30
CORRIDOR/JAN RECEP	31	720	4R	20	1	820	4R	20	1	100	32			
ICE MACHINE	33	1320	20	1	1320	20	1	1320	20	1	34			
CORRIDOR/JAN RECEP	35	540	3R	20	1	540	3R	20	1	36				
SPARE	37	20	1	0	0	0	0	0	0	38				
SPARE	39	20	1	0	0	0	0	0	0	40				
SPARE	41	20	1	0	0	0	0	0	0	42				
THROUGH FEED OR DOUBLE LUG TOTAL VA PER PHASE 0 0 0 PANEL:														
TOTALS														
KEY DEMAND DESIGN CONNECTED L-GENERAL LIGHTING LOAD 125% 0 VA 0 VA 38 TOTAL CONNECTED KVA R-RECEPTACLE LOAD (PER NEC ART. 220-13) 2880 VA 2880 VA 38 TOTAL DESIGN KVA M-MOTOR LOADS 0 VA 0 VA 105 TOTAL CONNECTED AMPS K-KITCHEN RECEPTACLES 0 AT 100% = 0 VA 0 VA 25% OF LARGEST MOTOR AMPS ALL OTHER LOADS 34840 VA 34840 VA 105 TOTAL DESIGN AMPS														

PANEL: BLPB VOLT : 208Y120V 3 PHASE, 4 WIRE BUS : 225 AMP MAIN : 150A, 3P FED FROM : BOB														
SURFACE MOUNTED 10 KAIC RATING NEMA 1 ENCLOSURE														
DESCRIPTION	W	U	W	U	W	U	W	U	W	U	W	U	W	U
PROC BSC	1	1764	20	1	3528	20	1	3528	20	1	1764	2	1	3528
PROC RECEPT.	3	360	2R	20	1	720	2R	20	1	360	3	1	720	3
PROC RECEPT.	5	360	2R	20	1	720	2R	20	1	360	6	1	720	6
PROC RECEPT.	7	540	3R	20	1	900	3R	20	1	540	10	1	900	10
PROC BSC	9	1764	20	1	3528	20	1	3528	20	1	1764	12	1	3528
PROC RECEPT.	11	360	2R	20	1	720	2R	20	1	360	14	1	720	14
PROC RECEPT.	13	360	2R	20	1	720	2R	20	1	360	16	1	720	16
PROC RECEPT.	15	360	2R	20	1	720	2R	20	1	360	18	1	720	18
PROC BSC	17	1764	20	1	3528	20	1	3528	20	1	1764	20	1	3528
PROC BSC	19	1764	20	1	3528	20	1	3528	20	1	1764	22	1	3528
PROC RECEPT.	21	540	3R	20	1	900	3R	20	1	540	24	1	900	24
PROC RECEPT.	23	360	2R	20	1	720	2R	20	1	360	26	1	720	26
PROC RECEPT.	25	360	2R	20	1	720	2R	20	1	360	28	1	720	28
PROC BSC	27	1764	20	1	3528	20	1	3528	20	1	1764	30	1	3528
PROC RECEPT.	29	360	2R	20	1	720	2R	20	1	360	32	1	720	32
PROC RECEPT.	31	360	2R	20	1	720	2R	20	1	360	34	1	720	34
PROC BSC	33	1764	20	1	3528	20	1	3528	20	1	1764	36	1	3528
PROC BSC	35	1764	20	1	3528	20	1	3528	20	1	1764	38	1	3528
SPARE	37	20	1	0	0	0	0	0	0	40				
SPARE	39	20	1	0	0	0	0	0	0	42				
SPARE	41	20	1	0	0	0	0	0	0	42				
THROUGH FEED OR DOUBLE LUG TOTAL VA PER PHASE 0 0 0 PANEL:														
TOTALS														
KEY DEMAND DESIGN CONNECTED L-GENERAL LIGHTING LOAD 125% 0 VA 0 VA 32 TOTAL CONNECTED KVA R-RECEPTACLE LOAD (PER NEC ART. 220-13) 10940 VA 11880 VA 31 TOTAL DESIGN KVA M-MOTOR LOADS 0 VA 0 VA 90 TOTAL CONNECTED AMPS K-KITCHEN RECEPTACLES 0 AT 100% = 0 VA 0 VA 25% OF LARGEST MOTOR AMPS ALL OTHER LOADS 20452 VA 20452 VA 87 TOTAL DESIGN AMPS														

PANEL: BLPC VOLT : 208Y120V 3 PHASE, 4 WIRE BUS : 225 AMP MAIN : 150A, 3P FED FROM : BOB														
SURFACE MOUNTED 10 KAIC RATING NEMA 1 ENCLOSURE														
DESCRIPTION	W	U	W	U	W	U	W	U	W	U	W	U	W	U
HOLDING RECEPT.	1	1560	20	1	3120	20	1	3120	20	1	1560	2	1	3120
PROC BSC	3	1764	20	1	3528	20	1	3528	20	1	1764	4	1	3528
PROC DED RECEPT.	5	180	1R	20	1	360	1R	20	1	180	8	1	360	8
HOLDING RECEPT.	7	1560	20	1	3120	20	1	3120	20	1	1560	10	1	3120
PROC BSC	9	1764	20	1	3528	20	1	3528	20	1	1764	12	1	3528
PROC DED RECEPT.	11	180	1R	20	1	360	1R	20	1	180	14	1	360	14
PROC BSC	13	1764	20	1	3528	20	1	3528	20	1	1764	16	1	3528
HOLDING RECEPT.	15	1560	20	1	3120	20	1	3120	20	1	1560	18	1	3120
PROC BSC	17	1764	20	1	3528	20	1	3528	20	1	1764	20	1	3528
PROC DED RECEPT.	19	180	1R	20	1	360	1R	20	1	180	22	1	360	22
HOLDING RECEPT.	21	1560	20	1	3120	20	1	3120	20	1	1560	24	1	3120
PROC BSC	23	1764	20	1	3528	20	1	3528	20	1	1764	26	1	3528
PROC DED RECEPT.	25	180	1R	20	1	360	1R	20	1	180	28	1	360	28
SPARE	27	20	1	0	0	0	0	0	0	30				
SPARE	29	20	1	0	0	0	0	0	0	32				
SPARE	31	20	1	0	0	0	0	0	0	34				
SPARE	33	20	1	0	0	0	0	0	0	36				
SPARE	35	20	1	0	0	0	0	0	0	38				
SPARE	37	20	1	0	0	0	0	0	0	40				
SPARE	39	20	1	0	0	0	0	0	0	42				
SPARE	41	20	1	0	0	0	0	0	0	42				
THROUGH FEED OR DOUBLE LUG TOTAL VA PER PHASE 0 0 0 PANEL:														
TOTALS														
KEY DEMAND DESIGN CONNECTED L-GENERAL LIGHTING LOAD 125% 0 VA 0 VA 32 TOTAL CONNECTED KVA R-RECEPTACLE LOAD (PER NEC ART. 220-13) 1800 VA 1800 VA 17 TOTAL DESIGN KVA M-MOTOR LOADS 0 VA 0 VA 69 TOTAL CONNECTED AMPS K-KITCHEN RECEPTACLES 0 AT 100% = 0 VA 0 VA 25% OF LARGEST MOTOR AMPS ALL OTHER LOADS 30120 VA 30120 VA 89 TOTAL DESIGN AMPS														

PANEL: BLPD VOLT : 208Y120V 3 PHASE, 4 WIRE BUS : 225 AMP MAIN : 150A, 3P FED FROM : BOB														
SURFACE MOUNTED 10 KAIC RATING NEMA 1 ENCLOSURE														
DESCRIPTION	W	U	W	U	W	U	W	U	W	U	W	U	W	U
SPARE	1	1560	20	1	3120	20	1	3120	20	1	1560	2	1	3120
SHELL SPACE	3	720	4R	20	1	900	4R	20	1	720	4	1	900	4
FUTURE PROC RM	5	1764	20	1	3528	20	1	3528	20	1	1764	6	1	3528
FUTURE PROC RM	7	180	1R	20	1	360	1R	20	1	180	8	1	360	8
FUTURE PROC RM	9	1764	20	1	3528	20	1	3528	20	1	1764	10	1	3528
FUTURE PROC RM	11	180	1R	20	1	360	1R	20	1	180	12	1	360	12
DITRYSTERILE CAGE WASH RECEPT.	13	720	4R	20	1	900	4R	20	1	1200	14	1	1200	14
DITRYSTERILE CAGE WASH RECEPT.	15	720	4R	20	1	900	4R	20	1	1200	16	1	1200	16
GRAN CAGE	17	720	4R	20	1	900	4R	20	1	1200	18	1	1200	18
PROC RM RECEPT.	19	900	5R	20	1	1480	5R	20	1	580	20	1	580	20
PROC RM BSC	21	1000	20	1	1580	20	1	1580	20	1	1000	22	1	1580
SPARE	23	20	1	0	0	0	0	0	0	24				
SPARE	25	20	1	0	0	0	0	0	0	26				
SPARE	27	20	1	0	0	0	0	0	0	28				
SPARE	29	20	1	0	0	0	0	0	0	30				</