

CONTRACTORS MUST OBTAIN ACCEPTANCE TEST PERMIT PRIOR TO FINAL CERTIFICATE OF OCCUPANCY

MECHANICAL EQUIPMENT SUBJECT TO THE MANDATORY REQUIREMENTS OF THE CALIFORNIA ENERGY EFFICIENCY STANDARDS, TITLE 24, MUST:

1. BE CERTIFIED BY THE MANUFACTURER AS COMPLYING WITH THE EFFICIENCY REQUIREMENTS AS PRESCRIBED IN SECTIONS:
  - SECTION 111 APPLIANCES REGULATED BY THE APPLIANCE EFFICIENCY STANDARDS.
  - SECTION 112 HVAC EQUIPMENT EFFICIENCY AND PACKAGED CONTROLS.
  - SECTION 113 SERVICE WATER HEATING EFFICIENCY AND PACKAGED CONTROLS.
  - SECTION 114 POOL AND SPA HEATING EFFICIENCY AND CONTROLS.
  - SECTION 115 RESTRICTIONS ON PILOT LIGHTS.
2. BE SPECIFIED AND INSTALLED IN ACCORDANCE WITH SECTIONS:
  - SECTION 121 REQUIREMENTS FOR VENTILATION.
  - SECTION 122 REQUIRED CONTROLS FOR HVAC SYSTEMS.
  - SECTION 123 REQUIREMENTS FOR PIPE INSULATION.
  - SECTION 124 REQUIREMENTS FOR DUCT INSULATION.

NOT USED	SCALE	4
	NONE	

---

TITLE 24 DOCUMENTATION[illegible]