

COPYRIGHT © FENTRESS ARCHITECTS	
ISSUED FOR	DATE
Pre-Schematic Design	07/14/2008
Schematic Design	07/28/2008
BID PK #1	10/08/2008
50% Program	10/24/2008
BID PK #1 80 CD	12/01/2008
BID PK #1 100 CD	02/16/2009
BID PK #2 100 CD	03/26/2009
100% CD	06/06/2009
CD 4	01/07/2010
COB 1	02/26/2010
COB 2	02/26/2010
CD 4	04/15/2010
RW PERMIT	05/05/2010
ASH008 RT	07/01/2010
ASH009	07/06/2010
ASH015	07/09/2010
ASH004	07/12/2010
ASH009B	07/16/2010
ASH010	08/13/2010
ASH011	08/27/2010
ASH020	08/29/2010
ASH018	11/17/2010
ASH028	12/15/2010
ASH028B2	01/14/2011
ASH028	01/21/2011

KEYNOTES:

- 4" E.A. DUCT UP, BALANCE TO 20 CFM
- 12" E.A. UP TO ABV. TRANSITION TO 8" AT 6" BSS CONNECTION. BALANCE TO 550 CFM
- 3/4" S.S. EVAC STUB OUT 3" RFI 461 FROM WALL AT 48" AFF. PROVIDE PLASTIC ENDCAP.
- 2" PVC EVAC UP.
- 6" E.A. DUCT UP FROM PASS THROUGH CONNECTION. BALANCE TO 50 CFM
- 10" IN AND TRANSITION TO 12" CONNECTION TO DECONTAMINATION CHAMBER. BALANCE TO 250 CFM. AIR BALANCE FOR DECONTAMINATION CHAMBER, GENERAL EXHAUST GRILLE, AND PHOENIX EXHAUST VALVE MUST OCCUR WHILE DECONTAMINATION CHAMBER IS IN EXHAUST /STANDBY PHASE.
- 8" E.A. UP TO ABV. TERMINATE DUCT ABV. CEILING TO BE CONNECTED TO 3" NEDERMAN SNORKEL. TRANSITION PIECE TO BE PROVIDED BY SNORKEL MFR. BALANCE TO 80 CFM
- 4" E.A. FROM VENTILATED CAGE CONNECTION UP TO ABV. BALANCE TO 40 CFM



FOR CONTINUATION SEE SHEET M22B23

PARTIAL MECHANICAL VIVARIUM PLAN - ZONE 2

SANFORD CONSORTIUM FOR REGENERATIVE MEDICINE

2880 TORREY PINES SCENIC DRIVE
LA JOLLA, CALIFORNIA 92037



Landmark/Phelps Consortium LLC
400 Broadway, Suite 1000
San Francisco, CA 94111
415.398.1000

FENTRESS ARCHITECTS
400 Broadway, Suite 1000
San Francisco, CA 94111
415.398.1000



SHEET NAME
PARTIAL MECHANICAL
VIVARIUM PLAN - ZONE 2

DRAWN BY: Author
PROJECT #: 200728.000
SHEET NUMBER

M22B22



SCALE
1/4" = 1'-0"

1

10/25/2008 4:55:10 PM
File: M22B22.dwg
User: fentress

Warning: It is a violation of the law for any person, unless acting under the direction of a licensed architect, to alter an item in any way. If an item in this document is altered, the altering architect, if other than the architect of record, shall affix the item his seal and the notation "altered by" followed by his signature and the date of such alteration, and the specific description of the alteration.