

COPYRIGHT © FENTRESS ARCHITECTS	
ISSUED FOR	DATE
Pre-Schematic Design	07/14/2008
Schematic Design	07/28/2008
BID PK #1	10/08/2008
50% Program	10/24/2008
BID PK #1 80 CD	12/01/2008
BID PK #1 100 CD	02/16/2009
BID PK #2 100 CD	03/26/2009
100% CD	08/08/2009
CD 4	01/07/2010
COB 1	02/26/2010
COB 2	02/26/2010
CD 4	04/15/2010
RW PERMIT	05/05/2010
ASH008 RT	07/01/2010
ASH005	07/05/2010
ASH015	07/09/2010
ASH004	07/12/2010
ASH009	07/16/2010
ASH010	08/13/2010
ASH011	08/27/2010
ASH003	08/29/2010
ASH021	11/05/2010
ASH018	11/17/2010
ASH026	12/16/2010

- KEYNOTES:
- 1/2" RC & 1/4" RL UP TO 2ND FLOOR.
 - 3/4", 5/8", & 3/8" REFRIGERANT PIPE UP TO 2ND FLOOR.
 - 3/4" RC & 3/8" RL UP TO 2ND FLOOR.
 - 12" DOWN TO 6" FUME HOOD, BALANCE TO 785 CFM.
 - 1" REFRIGERANT RELIEF PIPING, TERMINATE 15" ABOVE GRADE, LOCATE DIRECTLY BELOW WINDOW, COORDINATE W/ ARCHITECT.
 - 4" EA DUCT DN FOR X-RAY, STUB 4" BELOW CEILING, BALANCE TO 75 CFM.
 - BARI GA/B52-MT WIRELESS TEMPERATURE SENSOR PROVIDED BY PHOENIX CONTROLS, MOUNT SENSOR ON TACK BOARD, REFER TO ARCHITECTURAL FOR MOUNTING

