

12/22/2016 4:52:10 PM
P:\Projects\2017\Sanford Consortium for Regenerative Medicine\Drawings\MECHANICAL\4TH FLOOR\MECH 4TH FLOOR - ZONE 2.dwg
P:\Projects\2017\Sanford Consortium for Regenerative Medicine\Drawings\MECHANICAL\4TH FLOOR\MECH 4TH FLOOR - ZONE 2.dwg

Warning: It is a violation of the law for any person, unless acting under the direction of a licensed architect, to alter an item in any way. If an item in this document is altered, the altering architect, if other than the architect of record, shall affix the item his seal and the notation "altered by" followed by his signature and the date of such alteration, and the specific description of the alteration.

PARTIAL MECHANICAL FOURTH FLOOR PLAN - ZONE 2


SCALE
1/4" = 1'-0"

1

SHEET NAME
PARTIAL MECHANICAL FOURTH
FLOOR PLAN - ZONE 2



DRAWN BY: Author
PROJECT #: 200728.000
SHEET NUMBER

M2242



FENTRESS ARCHITECTS
400 West Broadway, Suite 200
San Diego, CA 92101
P: 619.594.1100
F: 619.594.1101
WWW.FENTRESSARCHITECTS.COM

Landmark/Phelps Consortium LLC
10000 Camino del Rio South, Suite 100
San Diego, CA 92108
P: 619.594.1100
F: 619.594.1101
WWW.LANDMARK-PHELPS.COM



SANFORD CONSORTIUM FOR REGENERATIVE MEDICINE
2880 TORREY PINES SCENIC DRIVE
LA JOLLA, CALIFORNIA 92037

ISSUED FOR	DATE
Pre-Schematic Design	07/14/2008
Schematic Design	07/28/2008
BID PK #1	10/08/2008
50% Program	10/24/2008
BID PK #1 80 CD	12/01/2008
BID PK #1 100 CD	02/16/2009
BID PK #2 100 CD	03/26/2009
100% CD	06/08/2009
CD 4	01/07/2010
COB 1	02/26/2010
COB 2	02/26/2010
CD 4	04/15/2010
RW PERMIT	05/05/2010
ASH008 RT	07/01/2010
ASH009	07/06/2010
ASH015	07/06/2010
ASH004	07/12/2010
ASH008A	07/18/2010
ASH010	08/13/2010
ASH011	08/27/2010
ASH020	08/28/2010
ASH018	11/17/2010
ASH028	12/15/2010
ASH028C2	01/14/2011

- KEYNOTES:
- 12" DOWN TO 6" FUME HOOD.
BALANCE TO 765 CFM.
 - 4" EA DUCT DN. BALANCE TO 20 CFM.
 - 10" EA DUCT DN TO 5" BSC. BALANCE TO
550 CFM.
 - GAP BA/BSC-WT WIRELESS TEMPERATURE
SENSOR PROVIDED BY PHOENIX CONTROLS.
MOUNT SENSOR ON TACK BOARD. REFER
TO ARCHITECTURAL FOR MOUNTING DETAIL.

