
[illegible]

Warning: It is a violation of the law for any person, unless acting under the direction of a licensed architect, to alter an item in any way. If an item in this document is altered, the altering architect, if other than the architect of record, shall affix to the item his seal and the notation "altered by" follows by his signature and the date of such alteration, and the specific description of the alteration.

SYMBOL LIQUID PIPE/GAS PIPE SIZE	
P1	3/4 / 7/8
P2	1/4 / 1/2
P3	3/8 / 5/8
P4	3/4 / 1 1/8
P5	3/4 / 1-1/8
P6	5/8 / 3/4

COPYRIGHT © FENTRESS ARCHITECTS	
ISSUED FOR	DATE
BID PK #1	10/08/2008
50% Progress	10/24/2008
BID PK #1 80 CD	12/01/2008
BID PK #1 100 CD	02/16/2009
BID PK #2 100 CD	03/26/2009
100% CD	05/05/2009
CD 4	01/07/2010
COSB 1 	02/26/2010
COSB 2 	02/26/2010
CD 5 	03/26/2010
RW PERMIT	05/05/2010
ASB00R1 	07/10/2010
ASB005 	07/06/2010
ASB015 	07/09/2010
ASB004 	07/12/2010
ASB000R2 	07/19/2010
ASB010 	08/13/2010
ASB011 	08/27/2010
ASB0120 	09/20/2010
ASB018 	11/17/2010
ASB019 	12/01/2010
ASB026R2 	01/11/2011
ASB028 	01/11/2011
ASB028R1 	01/28/2011
ASB018R1 	02/16/2011
RF#1#203  	02/16/2011
ASB1203 	04/01/2011

SANFORD CONSORTIUM FOR REGENERATIVE MEDICINE



CONSULTANT

 **Xanth**

Xanth Inc. | San Diego - North
5570 Oberlin Dr.
San Diego, CA 92121
858.597.0355 | fax 668.697.0565

Xanth #26084

Lankford/Phelps Consortium LLC
551 West Broadway, Suite 1400 San Diego, CA 92101
619.732.6600
619.732.1655 FAX

DAVIS DAVIS
ARCHITECTS
421 Broadway, Denver, CO 80202
303.733.5990



SHEET NAME
VARIABLE REFRIGERANT
SUPERHEATING

DRAWN BY: Author

SHEET NUMBER

M4007