



## PARTIAL PLUMBING FOURTH FLOOR PLAN - ZONE 2

SCALE  
1/4" = 1'-0"

1

P2242

SHEET NAME  
PARTIAL PLUMBING FOURTH  
FLOOR PLAN - ZONE 2  
DRAWN BY: Author  
PROJECT #: 200725.000  
SHEET NUMBERFENTRESS ARCHITECTS  
401 S. BROADWAY  
SAN ANTONIO, TEXAS 78202  
761.541.1111  
www.fentress.comLandfordPine Consortium LLC  
PRELIMINARY DRAWINGS  
PROGRESS DRAWINGS  
REVIEW DRAWINGS  
CONSTRUCTION DRAWINGS  
DATE: 4/14/10CONSULTANT  
xanth  
Sanford Pine Consortium  
San Diego, CA 92121  
619.592.0001  
www.xanth.comSANFORD CONSORTIUM FOR REGENERATIVE MEDICINE  
2880 TORREY PINES SCENIC DRIVE  
LA JOLLA, CALIFORNIA 92037

WORK ORDER NO. 431587

RW 2909

COPYRIGHT © FENTRESS ARCHITECTS

ISSUED FOR DATE

Pre-Schematic Design 07/14/2008

Schematic Design 07/28/2008

BID PK #1 10/05/2008

50% Progress 10/24/2008

BID PK #1 80 CD 12/01/2008

BID PK #1 100 CD 02/16/2009

BID PK #2 100 CD 03/26/2009

100% CD 05/08/2009

CD 4 01/07/2010

CD 1 02/26/2010

CD 2 02/26/2010

CD 4 04/15/2010

## KEY NOTES:

1. 2"LV DOWN, 1 1/2"LVW RISE.
2. (2) 1 1/2"DI DROP.
3. 1/2"CO2 DROP WITH SOV AT 96" AFF FOR INC.
4. 3/4"LV DROP WITH SOV AT 96" AFF FOR BSC.
5. 3/4"LV, 1/2"LA, 1/2"CO AND 1/2"COV DROP TO FUME HOOD.
6. 3/4"LV, 1/2"LA, AND 1/2"CO DROP.
7. PRESSURE REGULATOR SET AT 20 PSI ± CPM CAPACITY. PROVIDE 1/2" CAPPED TEE IMMEDIATELY UPSTREAM OF REGULATOR.
8. 3/4"LV AND 1/2"LA DROP AND CONNECT TO CEILING PANEL.
9. 1/2"CO DROP AND CONNECT TO CEILING PANEL.
10. 1/2"CO DROP AND CONNECT TO WATER POLYSHER.
11. 2"DOWN, 1 1/2"V RISE.
12. 1/2"COV AND 1/2"HW RISE.
13. 3/4"LV, 1/2"LA, AND 1/2"COV DROP.
14. 3/4"COV DROP AND CONNECT TO SINK DRAIN TAILPIECE.

