



COLUMN SCHEDULE									
LEVEL	COL. LABEL	COL. DIA.	COL. HGT.	COL. WID.	COL. THICK.	COL. REIN.	COL. TIE	COL. BAR	COL. DETAIL
LEVEL 3									
LEVEL 2									
LEVEL 1									
LEVEL B1									
LEVEL B2									
DETAIL									
LEVEL									

- COLUMN NOTES:**
- LONGITUDINAL REINFORCING IN COLUMNS SHALL BE ASTM A706.
 - FOUNDATION DOVELS SHALL MATCH COLUMN VERTICAL REINF. U.O.N. DOVELS SHALL EXTEND INTO FOUNDATION AND TERMINATE WITH A STANDARD HOOK, JUST ABOVE THE BOTTOM REINFORCING.
 - WHERE LONGITUDINAL COLUMN BARS ARE SHOWN CONTINUOUS, THEY MAY BE SPLICED AT THE CONTRACTOR'S OPTION. SPLICES SHALL CONFORM TO NOTES 4 THROUGH 8.
 - LAP SPLICES OF LONGITUDINAL REINF. (INCLUDING FOUNDATION DOVELS) SHALL BE:

BAR SIZE	SPLICE LENGTH
#8	5'-3"
#9	6'-0"
#10	6'-5"
#11	7'-5"
 - LAP SPLICES BETWEEN LONGITUDINAL BARS OF DIFFERENT SIZES SHALL BE THE LENGTH REQUIRED FOR THE LARGER BAR.
 - TYPE 2 MECHANICAL COUPLERS MAY BE USED IN LIEU OF LAP SPLICES AT LONGITUDINAL BARS.
 - WHERE LONGITUDINAL BARS ARE REQUIRED TO BE HOOKED, BAR TERMINATORS MAY BE USED IN LIEU OF HOOKS.
 - WHERE COLUMNS OCCUR INTEGRAL WITH WALLS, THE CONCRETE STRENGTH OF THE COLUMN MAY MATCH THAT SPECIFIED FOR THE WALL, IN LIEU OF THE STRENGTH SPECIFIED IN THE COLUMN SCHEDULE.