

22  
24  
26  
28  
30  
32  
34  
36  
38  
39  
40

A B C D E F G



| ISSUE    | DATE | DESCRIPTION            |
|----------|------|------------------------|
| 05.10.01 |      | PLAN CHECK SUBMITTAL   |
| 06.14.01 |      | PLAN CHECK RESUBMITTAL |
| 06.28.01 |      | RID SET                |
| 10.05.01 |      | QMA SET                |

PROJECT: 9985 SCALE: 1/8" = 1'-0"  
 DRAWN: T.L.A. CHECKED: L.G.  
 BUILDING 4  
 LOWER GARAGE LEVEL

**PLAYA DEL REY**  
 8700 PERSHING DRIVE  
 PLAYA DEL REY, CALIFORNIA 90293

**ARCHSTONE COMMUNITIES**  
 217 Technology Drive, Second Floor  
 Irvine, California 92618

**AMIPAM LDI Mechanical**  
 1700 BELLAIR STREET CORONA, CA 92709  
 (951) 449-8888 FAX (951) 449-8887 FAX  
 CA Lic. 19129

REGISTERED PROFESSIONAL ENGINEER  
 STATE OF CALIFORNIA  
 Exp. 06/30/2007  
 No. 102874  
 MECHANICAL

**GENERAL NOTES:**

- MECHANICAL EQUIPMENT / DUCTWORK SHALL BE MOUNTED ON 4" X 4" BRACKET WITH 1/2" DIA. ANCHORS. PORTS & 6"-2" ABOVE DRIVE AISLES & VAN ACCESSIBLE AREAS.
- CARBON MONOXIDE SENSORS SHALL BE MOUNTED IN STANDARD 4" X 4" BOX AT 5'-0" ABOVE FINISH FLOOR. SENSORS SHALL BE MOUNTED IN THE CENTER OF THE CONTROL PANEL WITH THE SENSING POINT PROVIDED BY THE ELECTRICAL CONTRACTOR.

**H.V.A.C. NOTES:**

- CARBON MONOXIDE SENSORS SHALL BE MOUNTED IN STANDARD 4" X 4" BOX AT 5'-0" ABOVE FINISH FLOOR. SENSORS SHALL BE MOUNTED IN THE CENTER OF THE CONTROL PANEL WITH THE SENSING POINT PROVIDED BY THE ELECTRICAL CONTRACTOR.

**GARAGE EXHAUST CALCULATION:**  
 78 SPACES X 14,000 X 0.0225 = 27,150 CFM

PLAN NORTH