

Los Angeles Lakers Headquarters

2275 East Mariposa Avenue
El Segundo, California 90245

RA Rec'd 030716
Returned 030916
RFI Code A1



Request for Information

RFI 201 - Specification Clarifications for Acoustical Treatments

<i>Date Submitted</i>	3/7/2016	<i>To</i>	Fred Hofmann	<i>From</i>	Michele Prata
<i>Date Required</i>	3/14/2016		Rossetti		Morley Construction Company
<i>Discipline</i>	Architectural		Tel: (313) 463-5151		Tel: 310-399-1600
<i>Author RFI Ref.</i>	None		fhofmann@rossetti.com		mprata@morleybuilders.com

<i>Document Ref.</i>	<i>Number</i>	<i>Title</i>	<i>Revision</i>
	095113	ACOUSTICAL PANEL CEILINGS	Jan 15, 2016 - No: 2
	098433	SOUND-ABSORBING WALL UNITS	Jan 15, 2016 - No: 2
	A-511	Enlarged Court Elevation	Jan 15, 2016 - No: 3
	A-512	Enlarged Court Elevation	Jan 15, 2016 - No: 3
	A-513	Enlarged Court Elevation	Jan 15, 2016 - No: 3

Question

Attachments None

Please confirm the following regarding acoustical treatments:

- ACT-1 should be 2'-0" X 2'-0" Armstrong Cirrus 589 per Finish Legend A-602 in lieu of products listed in Specification 09 51 13, Paragraph 2.3.
- Grid systems should be provided with manufacturers' standard hot-dipped galvanized coatings in lieu of galvanized coating designations listed in Specification 09 51 13, Paragraph 2.7. These are excluded by the manufacturer.
- Sound-Absorbing Wall Units at Court can be provided as Conwed / Wall Technology, Respond IR208 acoustical fabric wall panel with Gilford 2100 fabric, with 2" thick fiberglass core, and with 1/8" molded fiberglass. See design criteria listed on A-511 through A-513 elevations.

Answer

Date Answered _____ *Answered By* _____

- 1. Confirmed.
- 2. Confirmed.
- 3. Confirmed, verify compliance of proposed panel for use in type 1 construction. Per A-602, [FAB-1] BOD is Xorel. Proposed "Respond IR208" is available in a variety of fabrics. Submit fabric options for review and selection. (WW, P+W, 3/8/16)

This clarification is interpreted to be within the scope of referenced contracts issued in accordance with the Contract Documents, and without change in Contract Sum or Contract Time, and, as such, is not an authorization for work beyond the scope of the contract.