

## New PE

---

**From:** Tyler Minivan  
**Sent:** Friday, October 06, 2017 12:57 AM  
**To:** newPE@morleybuilders.com  
**Cc:** Jefferson Arthur  
**Subject:** Electrical Scope Coordination Items  
**Attachments:**

New PE,

There are some items that the electrical subcontractor will not include in its scope. Make sure you write these items into the elevator subcontract. The first item is provisions for card readers. The electrical subcontractor will help in the coordination and location but any conduit in the traveling cable must be provided by the elevator subcontractor. I can't recall who makes the final connections between the fire alarm relay and the elevator controllers. You will need to take a look at their bids to see who does what. Make sure to identify who does what in the contract. Also the electrical subcontractor will not provide temporary hook-up for the elevator guys.

Thanks,  
Tyler



Morley Construction Company | Benchmark Contractors, Inc.  
3330 Ocean Park Boulevard, Santa Monica, CA 90405  
[www.morleybuilders.com](http://www.morleybuilders.com)

