



- NOTES:
1. LOCATE SMALLER PENETRATIONS BETWEEN (E) CONCRETE PAN JOISTS & REFER TO DETAIL 7/LM-S-004 FOR STRENGTHENING REQUIREMENTS. REFER TO DETAILS 22/LM-S-501 AND 8/LM-S-501 AT LOCATIONS WHERE (E) CONCRETE PAN JOISTS ARE TO BE CUT.
  2. REFER TO ARCHITECTURAL & MECHANICAL DRAWINGS FOR LOCATION OF (N) PENETRATIONS IN (E) CONCRETE SLAB.
  3. CARE SHALL BE TAKEN DURING CONSTRUCTION TO AVOID DAMAGING (E) STRUCTURE. CONTRACTOR TO NOTIFY STRUCTURAL FOCUS & OWNER'S REPRESENTATIVE IF (E) STRUCTURE IS DAMAGED DURING CONSTRUCTION. CONTRACTOR IS RESPONSIBLE FOR REPAIRING SUCH DAMAGES. STRUCTURAL FOCUS NEEDS TO REVIEW REPAIR DETAILS PRIOR TO START OF THE REPAIR WORK.
  4. REFER TO NOTE 3 ON BASEMENT/FOUNDATION PLAN, 1/LM-S-201.

1 ROOF PLAN  
1/8"=1'-0"

