

THE POC INFORMATION ANY CHANGES REQUIRED BY LOW PRESSURE OR VOLUME SHALL BE THE SOLE RESPONSIBILITY OF THE CONTRACTOR.

POC #1: STATIC WATER PRESSURE 35 PSI DESIGN WATER PRESSURE 106 PSI > MAXIMUM SYSTEM DEMAND 12 GPM PRESSURE BOOST REQUIRED 91 PSI

5

CONTRACTOR SHALL ADJUST ALL HEADS AS REQUIRED TO ACCOMMODATE ANY VERTICAL OBSTRUCTIONS THAT MAY OCCUR, INCLUDING BUT NOT LIMITED TO LIGHT POLES, FIRE HYDRANTS, ETC. VERIFY ALL HEAD LAYOUT WITH OWNER'S AUTHORIZED

REPRESENTATIVE PRIOR TO STARTING WORK.

LATERAL LINE PIPING WITHIN BUILDING SHALL BE CPVC AND IS SHOWN FOR CLARITY ONLY, ACTUAL DESIGN AND ROUTING SHALL BE COMPLETED BY PLUMBING ENGINEER AND INSTALLED BY PLUMBING CONTRACTOR. EACH STUB-OUT WITHIN EACH PLANTER SHALL HAVE A CPVC FEMALE ADAPTER FOR THE LANDSCAPE CONTRACTOR angle CONNECTION. ALL PIPING THROUGH BUILDING TO EXTERIOR AND THROUGH BUILDING TO UPPER FLOOR SHALL BE PROVIDED BY PLUMBER.

sweeney + associates IRRIGATION DESIGN AND CONSULTING

38730 Sky Canyon Drive, Suite C Murrieta, Ca 92563 e: info@sweeneyassoc.com|t: (951) 461-6830 w: www.sweeneyassoc.com|f: (951) 461-6850

June 25, 2013

HLA 0000000-00000

PRÔJECT NUMBER

I HAVE COMPLIED WITH THE CRITERIA OF THE ORDINANCE AND APPLIED THEM ACCORDINGLY FOR THE EFFICIENT USE OF WATER IN THE IRRIGATION DESIGN PLAN