

SHEET NOTES:

1. FOR EXACT LOCATION AND CONTROL REQUIREMENTS OF HVAC AND PLUMBING EQUIPMENT REFER TO CORRESPONDING DRAWINGS.
2. PROVIDE EXTRA UNSWITCHED HOT WIRE FOR EXIT SIGNS. LOCATION AND QUANTITY OF EXIT SIGNS SHALL MATCH ARCHITECTURAL DRAWINGS.

KEY NOTES:

1. REFER TO SINGLE LINE DIAGRAM FOR CIRCUIT INFORMATION.
2. CARBON MONOXIDE SENSORS (BY HVAC CONTRACTOR). FOR QUANTITIES AND LOCATION REFER TO HVAC DRAWINGS. INTERCONNECT ALL SENSORS ON THIS PLAN WITH 3/4" CONDUIT AND RUN 1" CONDUIT FROM LAST SENSOR TO CARBON MONOXIDE CONTROL PANEL.
3. PROVIDE ADDITIONAL 1" TO MPOE AREA ON P1 LEVEL FOR EV CHARGER COMMUNICATIONS


DESIGN	DATE	REVISION
DATE	05/07/2015	Medium 02
DATE	09/04/2015	Medium 03
DATE	10/20/2015	Medium 04
DATE	05/27/2016	Medium 05



howard laks architects
1545 lincoln street
san jose, ca 95128
voice : 310-393-4465
fax : 310-393-2220

CONSULTANTS

Donald F. Dickerson Associates
CONSULTING MECHANICAL & ELECTRICAL ENGINEERS
1725 ALVARADO STREET, SUITE 404
SAN JOSE, CA 95126
TEL: 408.281.8888
FAX: 408.281.8888
E-MAIL: DONALD@DFA.COM



710 WILSHIRE BOULEVARD
MIXED-USE HOTEL PROJECT
SANTA MONICA - CALIFORNIA, 90401
PARKING FLOOR PLAN - P2

DRAWN	--
CHECKED	--
APPROVED	--
SCALE	1/8" = 1'-0"
SHEET	E-204
DATE	June 25, 2013
PROJECT NUMBER	HLA 0000000-00000